



**CLARIFICATION 2**

ލަންޕިންގ ޖަހާ ސަފުހާ 2

ނަންބަރު No:	TES/2019/W-15	
ފަންޑުގެ ނަންބަރު Project:	Construction of Ring Road at Gn.Fuvahmulah	
އުދުސެވުމުގެ ދުވަހު Issued Date	18 <sup>th</sup> March 2019	
ސަފުހާގެ އަދަދު No. of Pages: - 03	ބޯޖުގެ އަދަދު Boq: - 00	ޑްރޯއިންގް Drawings: - 00

Please include this amendment when submitting the bid.

**Below find clarifications for the queries which we have received.**

- Need Details & quantities for installation of Road Sign Boards  
**Project Number :-** TES/2019W-08-15  
**References-** All Technical Specification – 1/a/i/6 (Permanent work)  
**Road Traffic Sign Boards are not included as part of the scope of works for this project.**
- Need quantities or details (no. of intersections, etc..) for marking Zebra crossings at all Road intersections  
**Project Number :-** TES/2019W-08-15  
**References-** ALL BOQ - Road safety/Road marking  
**Road Traffic Sign Boards are not included as part of the scope of works of this project.**
- Need quantities or details (no. of intersections, etc..) for construction of speed breakers at all Road intersections  
**Project Number :-** TES/2019W-08-15  
**References-** All BOQ - Road safety/Road marking  
**We have provided all the available drawings with the bid document. It is the responsibility of the contractor to prepare any additional drawings required.**
- Need details for installation of PVC pipes (8", 6" & 4") – qnty. given (No. of pipes)  
**Project Number :-** TES/2019W-08, 12, 13  
**References:** BOQs – Gdh.Hanimaadhoo, S.Hulhumeedhoo & Th.Madifushi / Side walk/3.1.3 -3.15  
**8" will be used for interconnection of Settlement Tanks, 6" and 4" will be used as a provision for service lines.**



5. Need boq item and quantity for filling soil & compaction for sub grade of Dhuvaafaru site  
**Project Number :-** TES/2019W-11  
**Reference:** Drawings (Road Concepts) – Dhuvaafaru  
**Refer to BoQ item 4.1.1.**
  
6. Need boq item and quantity for Coral/rubble filling for green area of Dhuvaafaru site  
**Project Number :-** TES/2019W-11  
**Reference:** Drawings (Road Concepts) – Dhuvaafaru  
**Coral/Rubble filling for green area is not included as part of the scope of works of this project.**
  
7. Layout for Road drainage and Cable junctions are not shown in concept of Roads  
**Project Number :-** TES/2019W- 11  
**Reference:** Drawings (Road Concepts) – Dhuvaafaru  
**Installation of Cable Junctions or Settlement Tanks are not included as part of the scope of works of this project.**  
**For Storm Water Management System - Refer to Section IV Employer's Requirement, Scope of Works and Please refer to BoQ Item Number 1.3.2.**
  
8. Layout for Road drainage (only one side shown) and Cable junctions are not shown in concept of Roads  
**Project Number :-** TES/2019W- 15  
**Reference:** Drawings (Road Concepts) – Gn.Fuvahmulah  
**Installation of Cable Junctions or Gutters are not included as part of the scope of works of this project.**  
**For Storm Water Management System - Refer to Section IV Employer's Requirement, Scope of Works and Please refer to BoQ Item Number 1.3.2.**
  
9. Need BOQ item, Quantity, Details of Retaining wall  
**Project Number :-** TES/2019W-10  
**Reference :-** Drawing (Road concept/ Type 08) – B.Eydafushi  
**Construction of Retaining wall is not included as part of the scope of works for this project.**
  
10. Need concept types for Nooraanee Magu(S.No.#18) and Huravee Magu(S.No.#19) of B.Eydafushi Island  
**Project Number :-** TES/2019W-10  
**Reference :-** Drawing (Road concept) – B.Eydafushi/Concept of selected roads,  
Standard Tender Document - B.Eydafushi - Scope of works, Page -62  
**For the Concept of Nooraanee Magu and Huravee Magu, Refer to Type 03 of Road Concept Drawings – B.Eydafushi.**





11. Need concept type for School Magu(S.No.#12) of Hdh.Hanimaadhu Island

**Project Number :-** TES/2019W-08

**Reference :-** Drawing (Road concept) – Hdh.Hanimaadhu/Concept,  
Standard Tender Document - Hdh.Hanimaadhu \_Scope of works, Page -58

**We have provided all the available drawings with the bid document. It is the responsibility of the contractor to prepare any additional drawings required.**

**For Length and Width of the road please refer to Standard Tender Document, Hdh.Hanimaadhoo – Scope of Works.**

12. Layout for Cable junctions (only one side shown) is not shown in concept of Roads

**Project Number :-** TES/2019W- 08

**Reference:** Drawings (Road Concepts) – Hdh.Hanimaadhu/Road section Types -02, Type - 02A, Type -01B, Type-01,

**Type – 02A – Cable junctions need to be installed on both sides**

**Type – 01B - Cable junctions need to be installed on both sides**

**Type – 01 - Cable junctions need to be installed on both sides**

13. Mismatching details (widths) of Road & Side walk (see attachment CLARIFICATION DETAILS -02)

**Project Number :-** TES/2019W-08

**Reference:** Drawings (Road Concepts) – Hdh.Hanimaadhu/Road section Types  
Standard Tender Document - Hdh.Hanimaadhu \_Scope of works, Page -58

**For Correct Road Length and Width of the roads please refer to Standard Tender Document, Hdh.Hanimaadhoo – Scope of Works.**

ނަން

Name: Aishath Nadheema

අත්

Signature:



