

بِسْمِ اللَّهِ الرَّحْمَنِ الرَّحِيمِ



Ministry of Finance and Treasury
Ameenee Magu, Male', Republic of Maldives
Telephone: (960) 334 9266, Fax: (960) 332 0706

މިނިސްޓްރީ ޕްރޮވިޑެންޝަލް އޮފް ފިނޭންސް އަންޑް ޓްރެޝަރީ
އިދާރާތަކުގެ ތެރެއިން ، ފެން ، ލަވަ ، ދިރިއުޅޭ ތަކެތި

AMENDMENT 3

މަނުކުރުމުގެ ވަރުބަލި 3

ނަންބަރު No:	TES/2016/W-115	
ފަންޓުގެ ނަންބަރު Project:	Provision of Water Supply Facilities in B. Eydhafushi and Th. Vilufushi (Re-tender)	
ޖުމްލަ Issued Date	13 th November 2016	
ސަފުޙާގެ ނަންބަރު No. of Pages: -1	ބޯޕްގެ ނަންބަރު Boq: -00	ޖަލްދުގެ ނަންބަރު Drawings: -00

Please include this amendment when submitting the bid. ފަންޓުގެ ނަންބަރު ޖުމްލަ ސަފުޙާގެ ނަންބަރު ބޯޕްގެ ނަންބަރު ޖަލްދުގެ ނަންބަރު ހިމަނައިގެން ހުށަހަޅާށެވެ.

Please find below answers to the queries raised for the subjected project

Question: As per requirement (as per drawing shown in documents), these tanks are panel tanks where as GRP tanks does not come in panels and its only molded tanks, which is not possible by any means to supply of this huge sizes. (if GRP made in panels this cannot take load of heavy volumes of water

It is advisable to supply FRP or RTP panel tanks which are good for water and easy to assemble and to send from logistics point of view

Ans: Kindly note that the GRP tanks come under panels and can be assembled to required size easily. Bidder may quote for GRP tanks for unique evaluation of the bids and any change in tank material can be considered , if better quality and cost effective, after contract award.

Please be informed that the bid submission for the project will be held on **15th November 2016 at 1100hrs local time.**

ނަންބަރު
Name: Ahmed Mujuthaba

ސަފުޙާ
Signature: 

