



AMENDMENT 2

2 ވަނަ އަދަދު

ނަންބަރު No:	TES/2015/W-124		
ފަންޓެޔް Project:	Construction of Gdh Atoll council office building - Remaining works		
ދިނުމުގެ ތާރީޚު Issued Date	Sunday, 11 <sup>th</sup> October, 2015		
ސަފުހާގެ އަދަދު No. of Pages: -02	ބޯޖުގެ އަދަދު Boq: -01	ޑްރޯޕިންގ Drawings: -00	

Please include this amendment when submitting the bid. ބަދަލުކުރާ ޖެނެރަލް ބޯޖުގެ އަދަދު ބަދަލުކުރުމަށް ފަސޭހަވާ ގޮތުން ބަދަލުކުރާ ޖެނެރަލް ބޯޖުގެ އަދަދު ބަދަލުކުރުމަށް ފަސޭހަވާ ގޮތުން.

- A Revised BOQ is provided with this amendment.

**Answers for the queries raised during the clarification of the project.**

1. BOQ lists item as Demolition, leveling and cleaning of waste materials, more details required of this item

Answer: Please refer to proposed and existing floor plans and carefully observe site before quoting for this item.

2. Earth filling 300mm hardcore is listed in BOQ but for which work is unspecified.

Answer: Please refer to ground floor plan and elevations

3. Wall details are not shown in drawing.

Answer: Please refer to BOQ item 4.1 and 5.3 (solid blocks 150mm thick) dry wall should be 100mm thick.

4. Ceiling details.

Answer: External ceiling referred as toilet and eves ceilings.

5. Item 5.1 Ladder and railing details.

Answer: Please submit proposed drawings for ladder and refer existing details for stair case.

6. Doors and windows schedule error.

Answer: Please refer to BOQ item 7.1.1 and 7.1.2

Handwritten signature

7. Item 8.2 wall finishes

Answer: Please refer to revised BOQ

8. Detail drawing for reception and kitchen counter

Answer: Please refer to revised BOQ (Sizes and other necessary details mentioned in Revised BOQ, please submit proposed drawing or catalogues with respect of revised BOQ

9. Ground well details is not given in the drawing.

Answer: Assumed 15 meter away from proposed building and refer to revised BOQ

10. Septic tank details are not in the drawings.

Answer: No need to install septic tank, do only main connection to public network and refer to revised BOQ

11. Item 12.2 in BOQ lists replace all damage roofing sheets, more information on this item is required.

Answer: Please visit site and carefully observe superstructure before quoting for this item.

Please be informed that the **bid submission** for the project will be held on **Monday, 19<sup>th</sup> October 2015 at 10:00hrs**, Tender Evaluation section/Ministry of finance and Treasury.

تعمیر  
Name: Hussain Hameem

تعمیر  
Signature:

