

بِسْمِ اللّٰهِ الرَّحْمٰنِ الرَّحِیْمِ

Information Technology Division

Ministry of Health

ދިވެހިރާއްޖޭގެ ސަރުކާރުގެ ގެޒެޓް ގައި ބަޔާންކޮށްފައިވާ ގޮތުގައި  
ސިއްހަތުގެ ވަޑައިގަންނަވާ މިނިސްޓްރީގެ ދަށުން

### Specification for 8KVA UPS

<b>DETAILS</b>	<b>8KVA (Minimum) WITH AUTOMATIC VOLTAGE REGULATOR</b>
<b>FORM FACTOR</b>	<b>Rack mountable</b>
<b>OUTPUT VOLTAGE</b>	<b>220V, 230V (nominal), 240V</b>
<b>VOLTAGE DISTORTION FOR OUTPUT</b>	<b>Less than or equal to 5%</b>
<b>OUTPUT CONNECTION QUANTITY</b>	<b>Eight (8) IEC 320 C13 One(1) IEC 320 C19</b>
<b>INPUT VOLTAGE</b>	<b>220/230/240 V</b>
<b>INPUT CONNECTION TYPE</b>	<b>British BS1363A</b>
<b>BATTERY CONDITION</b>	<b>Leakproof</b>
<b>NUMBER OF BATTERY MODULE</b>	<b>2</b>
<b>REPLACEMENT BATTERY COST</b>	<b>Should include current market price for the replacement battery</b>
<b>INTERFACE PORTS</b>	<b>One (1) RJ-45 , One(1) Smart slot or equivalent interface port</b>
<b>AUDIBLE ALARM</b>	<b>Alarm when on battery Alarm when low battery Alarm when overload</b>
<b>REQUIRED FEATURES</b>	<b>Surge protection and Noise filtering Include Emergency Power Off feature LED Display with load and Status</b>
<b>RUN TIME</b>	<b>2 Hours with 5KV IT Load (Using Additional Battery Packs )</b>
<b>WARRANTY</b>	<b>One-year hardware and TWO years' service warranty One year Guarantee for Battery (provide replacement if battery life ends earlier than one year)</b>



*Aminath Sakha Saleem*

Aminath Sakha Saleem  
Computer Technician  
27<sup>th</sup> August 2019