




ELEVATIONS :	FINISH FLOOR LEVEL ↑			
DR / WD NO.		W1	W2	W3
DESCRIPTION :		ALUMINIUM FRAMED FIXED LOUVER WINDOW PANEL	ALUMINIUM FRAMED FIXED LOUVER WINDOW PANEL	ALUMINIUM FRAMED FIXED LOUVER WINDOW PANEL
FRAME :		80 MICRON WHITE POWDER COATED ALUMINIUM FRAME	80 MICRON WHITE POWDER COATED ALUMINIUM FRAME	80 MICRON WHITE POWDER COATED ALUMINIUM FRAME
HARDWARE :				
GLAZING :		6MM THICK HEAT REFLECTIVE GLASS	6MM THICK HEAT REFLECTIVE GLASS	6MM THICK HEAT REFLECTIVE GLASS

GENERAL NOTE FOR THE INSTALLATION OF DOORS:
ENSURE THAT ALL OPENING EXTERNAL BUILDING PERIMETER DOORS ARE LOCKABLE.
PERIMETER DOORS SHOULD MEET THE FOLLOWING BUILDING DESIGN STANDARDS:
– BE FITTED WITH A QUALITY SINGLE CYLINDER LOCKSET THAT COMPLIES WITH FIRE REGULATIONS.
– HAVE A METAL FRAME OR HAVE A STRIP OF METAL SECURELY MOUNTED TO THE FRAME FROM THE TOP TO THE BOTTOM OF THE LOCK-SIDE WITH ALLOWANCE FOR THE LOCK TONGUE TO BE INSERTED
– HAVE PROTECTED HINGE PINS IN ORDER TO RESIST REMOVAL BY EITHER REPLACING THE EXISTING HINGES WITH FIXED PIN OR SECURITY BUTT HINGES OR HAVING DOG BOLTS INSTALLED TO PREVENT PINS BEING REMOVED.
– ELECTRONIC LOCKS ON STAFF ONLY ACCESS DOORS
– ELECTRONIC ACCESS TO SENSITIVE AREAS E.G. PHARMACIES AND OTHER DRUG STORAGE AREAS / CUPBOARDS
– CCTV AND ADEQUATELY LIGHTING TO ALL AFTER HOURS PUBLIC ENTRIES AND EXITS
– VIDEO / CCTV INTERCOMS TO ALL AFTER HOURS RESTRICTED ENTRIES TO ALLOW SCREENING OF MEMBERS OF THE PUBLIC PRESENTING AT THE DOOR.
FIRE ISOLATED EXIT DOORS SHOULD MEET THE REQUIREMENTS OF THE BCA.

WINDOW SCHEDULE

SCALE 1:50