



NOTES:-

- ALL DIMENSIONS SHOWN ARE IN MILLIMETERS (MM), UNLESS OTHERWISE SHOWN
- ALL LEVELS SHOWN ARE IN METERS. ALL LEVELS SHOWN ARE FROM MEAN SEA LEVEL
- THIS DRAWING TO BE READ IN CONJUNCTION WITH ALL OTHER RELEVANT DRAWINGS, GENERAL NOTES AND SPECIFICATIONS.
- ALL NON-PRESSURE PIPES SHALL BE UPVC TO ASTM D-3034 SDR 35.
- ALL GRAVITY NETWORK LINES SHALL BE 160mm DIA.
- ALL GRAVITY NETWORK LINES SHALL HAVE MINIMUM 0.5% SLOPE.
- ALL NON-PRESSURE PIPES SHALL HAVE RUBBER SEAL JOINT.
- ALL LIFT STATIONS, MANHOLES AND CLEAN OUTS SHALL BE PLASTIC MOULDED TYPE.
- CONNECTION FROM THE HOUSEHOLD TO THE INSPECTION CHAMBER IS OUT OF THIS CONTRACT.
- PROVISION SHALL BE GIVEN IN IC FOR MULTIPLE CONNECTIONS.
- THE PIPE DIMENSIONS REPRESENT IN OUTSIDE DIAMETER (O.D).

REFERENCE DRAWINGS

SL.No	DRAWING No.	DESCRIPTION

REV.	DATE	DESCRIPTION	DRAWN	CHKD	APPRD.
0	15-09-15	DETAILED DESIGN SUBMISSION	JP	SS	MA

REVISION

CLIENT	MINISTRY OF ENVIRONMENT & ENERGY	REPUBLIC OF MALDIVES
--------	----------------------------------	----------------------

CONSULTANT:	استشاري
Al-Habshi Consultant	مكتب الحبشي للاستشارات الهندسية
Al-Habshi Consultants Office	
Tel.: 2430103 / 2433131 - Fax: 2431136	
P.O.Box 27154 Safat 13132 - Kuwait	

PROJECT:	Provision of Water Supply Facilities in 04 islands and Sewerage Facilities in 05 islands - N.Velidhoo Island - Republic of Maldives
----------	---

DRAWING TITLE:	SEA OUTFALL DETAILS-SHEET 03
----------------	------------------------------

DESIGNED	DRAWN	CHECKED	APPROVED	SCALE	DATE
AH	JP	SS	MA	AS SHOWN	15-09-15
PROJECT No.	SHEET No.	DRAWING No. NV-SW-113			
K-619	3 OF 3				
REV. No.	0				