



CLARIFICATION 1

1 ނަންބަރު 1 ގެ ސަބަބުން

ޕްރޮޖެކްޓް ނަންބަރު Pkg. No:	PSIP/2016/R		
ޕްރޮޖެކްޓް Issued Date:	29 th February 2016		
ޕްރޮޖެކްޓް Project:	(TES/2016/W-22) Construction of Gdh. Atoll School 3 Storey Building- Phase 2 (TES/2016/W-21) Construction of Gdh. Hoadehdhoo 5 Classroom and Supervisors Room (TES/2016/W-20) Construction of Gdh. Gahdhoo Mosque		
ޕްރޮޖެކްޓް Deadline for submission:	07th March 2016 (1100 hrs)		
ޕްރޮޖެކްޓް No. of Pages: -02	ޕްރޮޖެކްޓް BOQ: -00	ޕްރޮޖެކްޓް Drawings: -00	ޕްރޮޖެކްޓް Soft Copy: -00

Please include this clarification when submitting the bid.

މި ސަބަބުން ޕްރޮޖެކްޓް ނަންބަރު 1 ގެ ސަބަބުން ޕްރޮޖެކްޓް ނަންބަރު 1 ގެ ސަބަބުން

- Please find the below queries

Construction of Gdh. Atoll School 3 Storey Building- Phase 2 (TES/2016/W-22)

- 1) Are there any trees to cut down?
Ans: No
- 2) Can we make temporary accommodation at the site?
Ans: No
- 3) Can we use water from site for concrete mixing?
Ans: Yes
- 4) Can we use local sand for Masonry works?
Ans: Yes
- 5) What is the distance from the Electric Main DB?
Ans: 150 feet

Construction of Gdh. Hoadehdhoo 5 Classroom and Supervisors Room (TES/2016/W-21)

- 1) Are there any trees to cut down?
Ans: 25
- 2) Can we make temporary accommodation at the site?
Ans: No
- 3) Can we use water from site for concrete mixing?
Ans: Yes
- 4) Can we use local sand for Masonry works?
Ans: Yes
- 5) What is the distance from the Electric Main DB?
Ans: 100 feet



Construction of Gdh. Gahdhoo Mosque (TES/2016/W-20)

1) Are there any trees to cut down?

Ans: No

2) Can we make temporary accommodation at the site?

Ans: Temporary accommodation possible on site

3) Can we use water from site for concrete mixing?

Ans: fresh water for concrete mixing is available on site

4) Can we use local sand for Masonry works?

Ans: Salt free local sand can use only for brick making. For all other use, contractor should use manufactured sand

5) What is the distance from the Electric Main DB?

Ans: Electricity already provided on site

- The bid security amount of the project (Gdh. Gahdhoo Mosque) is **MVR35000.00** (as mentioned in the Invitation for Bids- (IUL)13-K1/13/2016/17 (11th February 2016))

Please note that the bid Opening will be held on **07th March 2016, 1100 hrs.**

 Name: Aminath Juweriya



 Signature: 