



**Ministry of Finance and Treasury**  
Ameenee Magu, Male', Republic of Maldives  
Telephone: (960) 3349106, Fax: (960) 3320706

ދިވެހިސަރުކާރުގެ ގެޒެޓް ގައި ބަޔާންކުރި ގޮތުގައި  
އިތުރު މަޢުލޫމާތު ހޯއްދެވުމަށް ދަންނަވަމެވެ.

AMENDMENT 1


1 0 0 0 0 0 0 0 0 0  
ހ ވ ސ ރ ބ ޅ ެ ީ ޮ ޯ

ޕްރޮޖެކްޓްގެ ނަންބަރު Pkg. No:	PSIP/2016/Q1		
ޕްރޮޖެކްޓް ނެރުވި ދުވަހު Issued Date:	25 <sup>th</sup> August 2016		
ޕްރޮޖެކްޓްގެ ނަންބަރު Project:	TES/2016/W-095 Construction of Gdh. Gahdhoo Health Centre TES/2016/W-096 Extension of Ga. Vilingili Hospital		
ޕްރޮޖެކްޓް ހުށަހަޅާ ދުވަހު Deadline for submission:	6 <sup>th</sup> September 2016 (1000 hrs)		
ޕްރޮޖެކްޓްގެ ނަންބަރު No. of Pages: -01	ޕްރޮޖެކްޓްގެ ނަންބަރު BOQ: -00	ޕްރޮޖެކްޓްގެ ނަންބަރު Drawings: -00	

Please include this clarification when submitting the bid. ސަފުޙާ 1 ގެ ޕްރޮޖެކްޓްގެ ނަންބަރު ގައި ބަޔާންކުރި ގޮތުގައި ހުށަހަޅާ ފޯމުގައި ބަޔާންކުރެއްވުމަށް ދަންނަވަމެވެ.

- Attached please find the answers for the questions raised regarding the projects

Please be informed that the bid opening for this package has been **postponed** to **Tuesday, 6<sup>th</sup> September 2016 at 1000hrs**, at Ministry of Finance and Treasury.

Name: Aminath Naheen Ahmed  
Signature: 



**PROJECT: - CONSTRUCTION OF GDH GADHOO HEALTH CENTER**

**QUERIES AND ANSWERS**

<b>#</b>	<b><u>Query</u></b>	<b><u>Answer</u></b>
1	Please the existing soil, site condition and demolition of any building, trees need to cut or transported, if demolition is there kindly provide the picture.	<ul style="list-style-type: none"><li>• <b>Contractor has to check soil condition before bidding.</b></li><li>• <b>Site is clear, No trees and building at site.</b></li></ul>
2	Can Ground water be used for construction purposes?	<ul style="list-style-type: none"><li>• <b>No. Desalinated water shall be used for all purposes, ground water shall not be used.</b></li></ul>
3	Please clarify the availability of the material storage & accommodation within the site premises.	<ul style="list-style-type: none"><li>• <b>Accommodation and material storage space available within Health center premises if space available. Site plan included in the tender document.</b></li></ul>
4	Please confirm whether temporary electricity & water can be obtained from site.	<ul style="list-style-type: none"><li>• <b>Contractor shall coordinate with utility company to establish temporary electric connection (all fees shall be paid by contractor)</b></li><li>• <b>No. Desalinated water shall be used for all purposes, ground water shall not be used.</b></li></ul>
5	Please confirm manufactured rock/sand can be used for structural concrete works	<ul style="list-style-type: none"><li>• <b>Yes. Manufactured sand shall be used for all purpose. In no circumstance local (sea) sand shall be used.</b></li></ul>
6	Can local sand be used for block making?	<ul style="list-style-type: none"><li>• <b>NO. Manufactured sand shall be used for all purpose. In no circumstance local (sea) sand shall be used.</b></li></ul>
7	Kindly provide the distance from the electrical main DB	<ul style="list-style-type: none"><li>• <b>Contractor shall check the distance from site before bidding.</b></li></ul>
8	Do you we have to quote for Inspection trips?	<p><b>Yes. Rates shall include for inspection trips for 2 people for 2 days, inclusive of transport and accommodation. Air tickets (normal fare) for 2 peoples (Male'/Kaadedhoo/Male').</b></p> <p><b>And speed boat (touring 36 or above) (Kaadedhoo /Gadhoo/ Kaadedhoo).</b></p> <p><b>Rates shall include inspection trips for consultant team (2 person) as above (for 04 trips).</b></p>

August 25, 2016



**PROJECT: - CONSTRUCTION OF HOSPITAL EXTENSION AT GA. VILINGILI**

**QUERIES AND ANSWERS**

<b>#</b>	<b>Query</b>	<b>Answer</b>
1	Please the existing soil, site condition and demolition of any building, trees need to cut or transported, if demolition is there kindly provide the picture.	<ul style="list-style-type: none"><li>• Contractor has to check soil condition before bidding.</li><li>• Site is clear, No trees and building at site.</li></ul>
2	Can Ground water be used for construction purposes?	<ul style="list-style-type: none"><li>• No. Desalinated water shall be used for all purposes, ground water shall not be used.</li></ul>
3	Please clarify the availability of the material storage & accommodation within the site premises.	<ul style="list-style-type: none"><li>• Accommodation space is NOT available within hospital premises. Can provide 50'X100' space for material storage.</li></ul>
4	Please confirm whether temporary electricity & water can be obtained from site.	<ul style="list-style-type: none"><li>• Contractor shall coordinate with utility company to establish temporary electric connection (all fees shall be paid by contractor)</li><li>• No. Desalinated water shall be used for all purposes, ground water shall not be used.</li></ul>
5	Please confirm manufactured rock/sand can be used for structural concrete works	<ul style="list-style-type: none"><li>• Yes. Manufactured sand shall be used for all purpose. In no circumstance local (sea) sand shall be used.</li></ul>
6	Can local sand be used for block making?	<ul style="list-style-type: none"><li>• NO. Manufactured sand shall be used for all purpose. In no circumstance local (sea) sand shall be used.</li></ul>
7	Kindly provide the distance from the electrical main DB	<ul style="list-style-type: none"><li>• Contractor shall check the distance from site before bidding.</li></ul>
8	Do you we have to quote for Inspection trips?	<p><b>Yes. Rates shall include for inspection trips for 2 people for 2 days, inclusive of transport and accommodation. Air tickets (normal fare) for 2 peoples (Male'/Kooddo/Male').</b> <b>And speed boat (touring 36 or above) (Kooddo/Vilingili/ Kooddo).</b> <b>Rates shall include inspection trips for consultant team (2 person) as above (for 04 trips).</b></p>

August 25, 2016

