



Ministry of Finance

Reconstruction of B.Kamadhoo Harbour

TES/2020/W-022

Clarification 1

Question	Answers
As per the section - 5 Scope of works - Design criteria (Point 2&3) specifies the sediment movement in to the harbor basin	There is no data to this matter at the moment. Our suggestion is to use core in any breakwater/groined that needs to be constructed. As EIA process is done by ministry we will inform the bidders if any design change is required. Otherwise proceed with the current design with breakwater and groined with a core.
The data on littoral drift with under water current study covering the seasons are necessary for orienting the entry channel	<u>For B. Kamadhoo</u> Existing channel is being utilized. There is no need to change the orientation of channel
The Provisional sum for the dismantling of existing breakwater & quay wall is not specified in the BOQ, can we include the costing details in additions. Kindly advice.	Revised BOQ will have in additions the demolition of existing quaywall/breakwater
Extension of time: the data collection may be involved, we request you to consider the extension of the tender for further - 15 days for the same.	Time extensions will be given accordingly. Ministry will extend after studying the situation and if it's necessary.

