

بِسْمِ اللّٰهِ الرَّحْمٰنِ الرَّحِیْمِ



Ministry of Finance

Ameene Magu, Male', Republic of Maldives

Telephone: (960) 334 9266, Fax: (960) 332 0706

ދިވެހިރާއްޖޭގެ ސަރުކާރުގެ
މިނިސްޓްރީ އޮފް ފިނޭންސް

CLARIFICATION 1

ކަނޑުވަޒަން ސަބަބުގެ 1

ނަންބަރު No:	TES/2020/W-007		
މަސައްކަތް Project:	Procurement of Design and Construction Works of the Infrastructure, Road and Land Point for the Waste Transfer Facility at Gdh. Vaadhoo		
އިއުޅުކުރުމުގެ Issued Date	March 1, 2020		
ދަފްތަރުގެ ދަތުރު No. of Pages: -1	<table border="1"> <tr> <td>މަޢުލޫމާތު BoQ: -00</td> <td>މަޢުލޫމާތު Drawings: -00</td> </tr> </table>	މަޢުލޫމާތު BoQ: -00	މަޢުލޫމާތު Drawings: -00
މަޢުލޫމާތު BoQ: -00	މަޢުލޫމާތު Drawings: -00		

Please include this amendment when submitting the bid.
 ޖާ ރިޔާޔަތްކުރުމަށް ރުޖުވާ ސަބަބުގެ ސަބަބުން ސަބަބުގެ ސަބަބުން ސަބަބުގެ ސަބަބުން

- Clarifications are given in the below table

#	Queries	Answers
1	Bidding document - Section VI – Tendering forms - Scope of works (page 66) mentioned as Brief description of work but there is no details provided, kindly provide the scope of works	Scope work has been defined In the technical specification
2	Boundary wall to be constructed? If yes, what is the minimum height of compound wall?	A boundary fence of total height 3.04m (10ft). A wall of height 0.914m of (3ft) rest of height to be a mesh fence
3	Is there any machinery/equipment to be supplied? If yes means what are the list of equipment to be procured by contractor	Procurement of equipment and machinery not included in the contract
4	Container refilling area slope surface reinforced concrete required?	Slope of ramp and length to be designed by the contractor, ramp should be suitable for heavy vehicle to go up and down. Reinforcement will be required for the slab as heavy vehicle are expected to be used to load containers
5	In container refilling – Flat surface area around the boundary RCC wall required?	Yes RCC wall required including RCC slab for flat surface
6	Please specify container tipping and waste shredder area roofing is required or not?	Roof is required
7	The waste shredder procurement is under the scope of contractor?	Procurement of equipment and machinery not included in the contract

ނަންބަރު
Name: Fathimath Rishfa Ahmed

ސަބަބު
Signature:

