



وسرم على مرق وسرس في المراق ا

## **CLARIFICATION 05**

روم و من من و 5 ما و مروم من من و 5

سرسره مر No:	TES/2020/W-0	53	
Project:	Design-Build of Male' and Vilimale' Waste Transfer Station including supply and installation of equipment		
هُرِيرُ Issued Date	24 <sup>th</sup> August 2020		
بروری مرترو No. of Pages: -02	Boq: -00	يروريو Drawings: -00	

Please include this clarification when submitting the bid

Please find attached, answers to the queries received.

Name: Fathimath Rishfa Ahmed

Signature:

## **CLARIFICATION 5**

#	Section / Document	Question	Response
1		In Appendix 1: Terms and Procedures of Payment, we have confusion on payment terms and payment procedures of the payment for Equipment and Mandatory Spare Parts Supplied from Abroad. According to Terms of Payment, 80% of the purchasing price shall be paid by irrevocable confirmed letter of credit upon submission of document, and 20% shall be paid against the acceptance certificate issued by the purchaser; while in Payment Procedures, there is a 10% advance payment will be paid against an irrevocable advance payment security, and other 90% will be paid against the documents required. What's the payment terms of payment and procedures for the equipment exactly?  Whether Letter of Credit will be applied as the payment terms for equipment, or the employer also accept alternative payment terms?	Please refer to addendum 4
2	Section 3 – 2.4.1	May the Employer / Engineer consider if the similar contract defined under 2.4.1 shall be completed within the last 8 years, instead of last 5 years?	Please refer to Addendum 4
3	Section 6 - Employer's Requirements, 4.8 Interfaces, b) water supply	The transfer point shall be the output flange of the water meter installed by Male Water and Sewerage Company, MWSC, at the premises boundary. During the construction period it shall be subject to the considerations of the Contractor how to supply the required amount of water.  Could the MWSC supply continuous water with 30L/S capacity @ 35m head to guarantee the domestic and firefighting water supply at the premises boundary? If not, should the Contractor consider water tanks and pumps for the domestic and firefighting water supply.	The water network laid by MWSC is to cater the municipal utility requirements in accordance with EPA. Hence the requested firefighting water requirement cannot be provided at the locations of WAMCO sites in Male' and Vilingilli.

