



Ministry of Finance
Ameene Magu, Male', Republic of Maldives
Telephone: (960) 334 9266, Fax: (960) 332 0706

ދިވެހިސަރުކާރުގެ ގެޒެޓް
ދިވެހިސަރުކާރުގެ ގެޒެޓް، ދަފުތަރު، ދިވެހިސަރުކާރުގެ

CLARIFICATION 2

މަޢުލޫމާތު ސުވާލުގެ ޖަވާބު

ސަރުކާރުގެ ގެޒެޓް No:	TES/2019/W-007	
ޕްރޮޖެކްޓްގެ ނަންބަރު Project:	Harbour Rehabilitation, Waste Processing, Administrative Building, Workshop and Civil Works (Platform) for C&D Plant, Recycling Yard, and ELV Dismantling workshop at Thilafushi (PackageNo.CW/01).	
އުފުލާ ދުވަހު Issued Date	25 th March 2019	
ސަފުޙާ ގެ ޖަދުވަލު No. of Pages: -03	ބޯޖު Boq: -00	ނިޔަންމު ވަރަށް Drawings: -00

Please include this clarification when submitting the bid. ބަދަހުގެ ދުވަހުގެ ތެރޭގައި މި ޖަވާބު ހިމާނައިގެން ބަދަހު ހުށަހަޅާން ޖެހޭނެއެވެ.

➤ Attached please find the clarifications.

Please be informed that the deadline for bid Submission is 1st April 2019 at Ministry of Finance, National Tender.

ނަންމު
Name: Ahmed Mujuthaba

ސަފްތާ
Signature:



Clarification 02
Harbour Rehabilitation, Waste Processing, Administrative Building, Workshop and Civil Works
(Platform) for C&D Plant, Recycling Yard, and ELV Dismantling workshop at Thilafushi
(PackageNo.CW/01).

N°	Clarification	Answer
1	Regarding to BOQ item 2.2 Transport of surplus material from general earthworks, please clarify:	
a	location of dump point	Dumpsite next to the Site
b	distance from site to dump point	Less than 50 m
2	During construction period of 610 days, please clarify if there will be any operation by Employer or Employer's subcontractors occur on construction site. If so, please clarify operation area on drawing.	Yes there will be. The works has to be made portion wise in coordination with WAMCO (Waste management corporation). Operation area during 1 st phase of the work (eastern part) could be the north-western part of the side and vice versa
3	Please clarify iron reinforcement strength for foundation, slab, beams and columns. 500B as in BOQ item 5 or 420 as in provided drawing?	500 B
4	Refer to Work Programme on Page 363 of Section 6 Employer's Requirement, please clarify whether this diagram is just our reference or mandatory compliance. Especially for construction carriageway, the scheduled period of 2 month shown on work programme is not reasonable enough since large amount of concrete involved.	The diagram is just for reference nevertheless the overall times schedule should be kept as a reasonable timeframe and should not be unreasonably extended.
5	Ground water can be used for construction	Groundwater is brackish water, contains a high amount of salt and should not be used for construction without any treatment (desalination).
6	Please clarify the availability of material storage & Accommodation	please check with local suppliers
7	Please confirm whether temporary Electricity & water can be obtained from site	Yes confirmed, the contractor shall take liaise with STELCO and Male' water and Sewerage company
8	Please confirm Rock sand can be used for structural Concrete works	Yes
9	Can use local sand for Block making	No river sand only
10	Kindly provide waste water disposal layout	Needs to be coordinate and defined by EPA/Wastewater company
11	Kindly provide Auto CAD drawings	You may download from link below.

Se



N°	Clarification	Answer
		https://ocs.kocks-ing.de/index.php/s/VfhjUZKzRZmcme0
12	Although it is mentioned in the Invitation for Bids that this contract includes Harbour Rehabilitation and Waste Processing, this scope of work is not included in the BOQ	No the official designation of the area is “waste processing area and the scope of work is a sort “harbour rehabilitation”. The contractor has to follow the description and the BoQ
13	West Boundary of the project is not shown in the layout drawings.	The West boundary ends with the start of the existing dumpsite. It is more or less limited by the green area
14	Should the removal of existing garbage dump be done by the contractor of this package	The site has been already more or less cleared by WAMCO. Remaining waste should be brought to the adjacent dumpsite. Existing garbage dump should be priced under item “site clearance”

- The bid shall be sealed and marking on the bids should be in accordance with Section 1, ITB 21. :

- (a) Bidders submitting Bids by mail or by hand shall enclose the original of the Technical Bid, the original of the Price Bid, and each copy of the Technical Bid and each copy of the Price Bid, in separate sealed envelopes, duly marking the envelopes as “ORIGINAL - TECHNICAL BID,” “ORIGINAL - PRICE BID,” and “COPY NO... - TECHNICAL BID” and “COPY NO.... - PRICE BID.” These envelopes, the first containing the originals and the others containing copies, shall then be enclosed in one single envelope per set. If permitted in accordance with ITB 13, alternative Bids shall be similarly sealed, marked and included in the sets. The rest of the procedure shall be in accordance with ITB 21.2 and ITB 21.5.

S.S.

