



SLD FOR PROPOSED TREATMENT FACILITY FOR ADH. KUNBURUDHOO

NOTE :-
SINGLE LINE DIAGRAM IS INDICATIVE AND FOR REFERENCE. CONTRACTOR SHALL BE DESIGN THE SYSTEM AS PER REQUIREMENT.
1. ALL DIMENSIONS ARE IN MM UNLESS AND OTHERWISE SPECIFIED.

PROTECTION:-
OVERLOAD RELAY, SINGLE PHASE PREVENTOR AND EARTH FAULT RELAY PROTECTION

◀◀□▶▶ CIRCUIT BREAKER
-O- TRANSFORMER (VT-VOLTAGE TRANSFORMER)
E SINGLE LINE CURRENT TRANSFORMER

DOL STARTER
⊗ PHASE HEALTHY INDICATION LAMPS (R.Y.B-RED. YELLOW. BLUE.)
★ STAR DELTA STARTER
LPBS LOCAL PUSH BUTTON STATION
VFD VARIABLE FREQUENCY DRIVE

INSTRUMENTATION:-

ASS AMMETER SELECTOR SWITCH
A AMMETER
VSS VOLT SELECTOR SWITCH
V VOLTMETER
MFM MULTI FUNCTION METER CONSISTS OF KVA.KW.KVAR A.V.POWER CTOR AND FREQUENCY METER, KVAH, KWH, KVARH WITH PORT

REVISION				
No.	DESCRIPTION	BY	DATE	APPR.
CONSULTANT				
SHAH TECHNICAL CONSULTANTS PVT. LTD., INDIA				
IN ASSOCIATION WITH				
DEVELOPMENT TECHNOLOGIES MALDIVES, MALDIVES				

TENDER PURPOSE				
CLIENT				
MINISTRY OF ENVIRONMENT AND ENERGY				
MALE' REPUBLIC OF MALDIVES				
PROJECT				
PROVISION OF RAINWATER HARVESTING SYSTEM IN 8 ISLANDS				
ASSIGNMENT				
CONSULTANCY SERVICES FOR DESIGN AND SUPERVISION OF RAINWATER HARVESTING SYSTEM IN AA. HIMANDHROO, AA. BODUPULHADHOO, AA. MATHIVELI, ADH. KUNBURUDHOO, ADH. DHIGURAI, DH. BANDERHOO, DH. HULHEDHIELI, DH. MEEDHROO, MALDIVES (PACKAGE - 3)				
DRAWING TITLE				
SLD FOR PROPOSED TREATMENT FACILITY FOR ADH. KUNBURUDHOO				
APPROVED		DESIGNED	DESIGNED	DESIGNED
SPK		SDB	SDB	JAD
SCALE		DATE	DRAWING NUMBER	REVISION
AS SHOWN		FEB 2018	Adh. Kunburudhoo/EL/01	0