




NOTES:-

1. ALL DIMENSIONS SHOWN ARE IN MILLIMETERS (MM), UNLESS OTHERWISE SHOWN
2. ALL LEVELS SHOWN ARE IN METERS.
ALL LEVELS SHOWN ARE FROM MEAN SEA LEVEL
3. THIS DRAWING TO BE READ IN CONJUNCTION WITH ALL OTHER RELEVANT DRAWINGS, GENERAL NOTES AND SPECIFICATIONS.
4. ALL NON-PRESSURE PIPES SHALL BE UPVC TO ASTM D-3034 SDR 35.
5. ALL GRAVITY NETWORK LINES SHALL BE 160mm DIA.
6. ALL GRAVITY NETWORK LINES SHALL HAVE MINIMUM 0.5% SLOPE.
7. ALL NON-PRESSURE PIPES SHALL HAVE RUBBER SEAL JOINT.
8. ALL LIFT STATIONS AND MANHOLES SHALL BE PLASTIC MOULDED TYPE.
9. CONNECTION FROM THE HOUSEHOLD TO THE INSPECTION CHAMBER IS OUT OF THIS CONTRACT.
10. PROVISION SHALL BE GIVEN IN/C FOR MULTIPLE CONNECTIONS.
11. THE PIPE DIMENSIONS REPRESENT IN OUTSIDE DIAMETER(O.D).

REFERENCE DRAWINGS							
DRAWING No.		DESCRIPTION					
0	15-09-'15	DETAILED DESIGN SUBMISSION			JP	SS	MA
REV.	DATE	DESCRIPTION			DRAWN	CHKD.	APPRD.
REVISION							
CLIENT							
 <div style="text-align: center;"> MINISTRY OF ENVIRONMENT & ENERGY REPUBLIC OF MALDIVES </div>							
CONSULTANT:							
 <div style="text-align: right;"> استشاري مكتب الحبشي للاستشارات الهندسية Al-Habshi Consultants Office Tel: 2430103 / 243131 - Fax : 2431136 P.O.Box 27154 Safat 13132 - Kuwait </div>							
PROJECT:							
Provision of Water Supply Facilities in 04 islands and Sewerage Facilities in 05 islands - GA.Kolamaafushi Island - Republic of Maldives							
DRAWING TITLE:							
PLASTIC MANHOLE DETAILS GA.KOLAMAAFUSHI ISLAND							
DESIGNED	DRAWN	CHECKED	APPROVED	SCALE	DATE		
SK	JP	SS	MA	AS SHOWN	15-09-'15		
PROJECT No.		SHEET No.		DRAWING No.			
K-619		1 OF 1		KO-SW-134			
REV. No.		0					