



CLARIFICATION 1

1 ވަނަ ބަޔާން

ނަންބަރު No:	TES/2022/W-006		
ޕްރޮޖެކްޓް Project:	Construction of New Building at N. Maalhendhoo School		
ޕްރިންޓް Issued Date	24 th February 2022		
ސަފުހާ ގެ އަދަދު No. of Pages: -1	ބީޕީއެލް BoQ: -00	ޑްރޯޕިންގ Drawings: -00	

Please include this Clarification when submitting the bid. ބަޔާން ފުރިހަމަކުރުމުގެ ތެރޭގައި މި ބަޔާން ހިމަނާން ޖެހޭނެއެވެ.

➤ **Please find below the answers to the queries raised**

QUERIES	RESPONSES
Can we request the location for Temporary accommodation and material storage?	Yes. But no space is available in school.
Is there any demolition work at site?	Demolition Plan is in the drawing set. Please refer to the drawings
Is water and electricity facility availability at site?	Contractor have to request for a separate temporary water and electrical connection from (Fenaka/Stelco)
Status of Harbor for Landing Craft.	Its bidder's responsibility to get this information from island council.
How far from peoples living area to work site?	Its bidder's responsibility to get this information from island council.
Is there any near spot to take electricity for work site and the distance?	Electricity can be taken from School.
Is there any waste collection area for construction materials?	No
Can we use island ground water for construction work?	If water does not contain impurities that affect concrete and reinforcement ground water can be used.
How many trees are in work site? removal or relocation is required?	There is one tree in the work site which has to be removed.
Can we use local sand for block making?	Yes. It is recommended to rinse the sand to remove salts.

ނަންބަރު
Name: Fathimath Rishfa Ahmed

ސަފްޞާޙާ
Signature: