

Construction of N. Kendhikuludhoo Hospital, Under Contractor Finance

CLARIFICATION - 2

	Query	Response
1	1. What is the condition of existing site? Are there any demolishing works or for cutting trees?	There are no demolition works but lot of coconut trees at site, we would recommend to inspect the site
2	2. Can we get water and electricity for construction work under existing site condition?	(i) There is no electricity connection at the site, please coordinate with fenaka to get temporary or permanganate connection. (ii) Ground water cannot be used, desalinated water must be use and desalinated water available in the island
3	3. Is there any space for material storage?	MoH can provide Proposed hospital land to the contractor, contractor will manage material storage withing the site, if additional space required, please coordinate with island council
4	4. Can we get cad drawing?	Provided with the bid document.
5	5. Details of solar system?	Technical specification provided with the bid document
6	6. Details of medical scope of works like oxygen system medical air system etc	Technical specification provided with the bid document
7	7. The drawing (hospital building, Accommodation & service) is related to this island?	Yes
8	8. ACMV units are differ from BOQ & Drawing. Mechanical vent in toilets are shown in drawing but missing in BOQ which one to follow	Please include mechanical vents in additional bill



MPC