



Ministry of Finance  
Ameenee Magu, Male', Republic of Maldives

މިނިސްޓްރީ ޕްރޮޓެކްޝަން ޕްރޮޓެކްޝަން  
މިނިސްޓްރީ ޕްރޮޓެކްޝަން ޕްރޮޓެކްޝަން

CLARIFICATION 2

މަޢުލޫމާތު ޖަވާބު 2

ނަންބަރު No:	TES/2022/G-018	
ފްރޮޕްޖެކްޓް Project:	Design, Supply, Installation and Maintenance of Ice Making Plants from Sea Water in 4 Islands (N.Landhoo, Th.Buruni, Th.Madifushi & Th.Villufushi)	
ޖަވާބު Issued Date	28 <sup>th</sup> February 2023	
ސަފުހާ ގެ ޖަވާބު No. of Pages: -03	ބޮޕް Boq: -00	ޖަވާބު Drawings: -00

Please include this clarification when submitting the bid

މި ޖަވާބު ފަންޖަރު ޖަވާބު ޖަވާބު ޖަވާބު ޖަވާބު ޖަވާބު ޖަވާބު ޖަވާބު ޖަވާބު ޖަވާބު

- Please find attached, answers to the queries received.

ނަންބަރު  
Name: Fathimath Rishfa Ahmed

ޖަވާބު  
Signature:



**CLARIFICATION 02**

#	Document Name	Document Reference (Section no/page no etc)	Query	Response
1	Bidding Document	Bidding document- Schedule No. 1: Plant and Mandatory Spare Parts Supplied from Abroad  Section 6-2.2 Ice Making Plant-Technical Specification	<p>Containerized flake Ice making plant <b>15 T/day</b>. Flake Ice Plant. Ice plant on top and storage at bottom. Ice drop directly to storage. Refrigerant type: R404A. 400V, 3Phase, 50Hz system. Automatic rake ice storage for automatic ice levelling. Ice making from sea water. Internal components shall be made from rust free material similar to SS304. Storage room capacity <b>35 T</b></p> <p>Containerized flake Ice making plant <b>5 T/day</b>. Flake Ice Plant. Ice plant on top and storage at bottom. Ice drop directly to storage. Refrigerant type: R404A. 400V, 3Phase, 50Hz system. Automatic rake ice storage for automatic ice levelling. Ice making from sea water. Internal components shall be made from rust free material similar to SS304. Storage room capacity <b>15 T</b></p> <p>• Ice Storage Room Capacity up to <b>30 Tonnes (1 unit) and 15 Tonnes (3 units)</b> with stainless steel or polyethylene interior for easy cleaning and should resist scratches and scuffs from ice scoops</p>	35T x 3 units, 15T x 1 units
2			Whether build the ice factory at the pier, and then uses a screw conveyor to transport the ice to the ice storage bin on the fishing vessel? (Is the ice bin on the fishing vessel)	conveyor system upto fishing boat is not required. However, from tye storage container to building exit point shall be arranged
3			We can provide an integrated ice maker, so that the refrigeration system does not need a machine room, is this acceptable?	The complete system shall meet the technical specification provided in the tender document.
4			We think that the 15-ton and 35-ton ice storage rooms do not need a rack system. The cost of the rack system is high, and it is generally used in large-capacity ice	Rack system is required.



		storage rooms or factories that require mixed materials. But if you need, we can also provide.	
5		<p>This is with reference to the Tender # TES/2022/G-018, Document # Plant1S1E Section1_ITB, Clause 21 (attached herewith) pertaining to Bid Security/Bid Security declaration</p> <p>Point# 21.3:</p> <p>If a bid security is specified pursuant to ITB 21.1, bid security shall be, at the Bidder's option, in any of the following forms:</p> <ul style="list-style-type: none"> <li>(a) an unconditional bank guarantee,</li> <li>(b) an irrevocable letter of credit, or</li> <li>(c) a cashier's or certified check.</li> </ul> <p>We would like to request you to kindly consider accepting our company's ' Insurance Bond' as the Bid Security in lieu of the above mentioned three options. This will facilitate us to expedite our submission.</p>	Bid Security should be submitted in a form specified in the Bidding Document.

*Handwritten signature*

