

Amendment 1 for package number: PSIP /2016/E

Invitation number: (IUL)13-K1/13/2016/15

Construction of Hdh. Finey school staffroom and Boundary wall. (TES/2016/W-14)

1. Are there any trees to cut down?
There is one Banyan tree. Contractor advised to check site condition by themselves
2. Is there any building to be demolished at site?
Old boundary wall of perimeter 837ft and 5 foot height
3. Can we make temporary accommodation at the site?
No
4. Can we use ground water from site for any concrete or masonry work?
Can be used, If the water condition is to the standard.
5. Can we use local sand for Masonry works?
No
6. What is the distance from the Electric Main DB?
200 ft
7. Is the project Lamp sum of Measure and Pay?
It is a lamp sum project.
8. What is the distance from the jetty to the site?
3200 ft
9. Do we have to start the construction works together?
yes

If any Discrepancies from the drawing or BOQ, include it in The Addition and Omission



Construction of Hdh. Makunudhoo School 2 storey building -10 classroom. (TES/2016/W-15)

1. Are there any trees to cut down?

There are three trees to cut down. Contractor advised to check site condition by themselves.

2. Is there any building to be demolished at site?

No.

3. Can we make temporary accommodation at the site?

No.

4. Can we use ground water from site for any concrete or masonry work?

Can be used, if the water condition is to the standard.

5. Can we use local sand for Masonry works?

No.

6. What is the distance from the Electric Main DB?

79ft

7. Is the project Lamp sum of Measure and Pay?

It is a lamp sum project.

8. What is the distance from the jetty to the site?

Round 1500ft

9. Do we have to start the construction works together?

yes

If any Discrepancies from the drawing or BOQ, include it in The Addition and Omission



Construction of 9 classroom block at Hdh. Vaikaradhoo. (TES/2016/W-16)

1. Are there any trees to cut down?
2 tree
2. Is there any building to be demolished at site?
Yes, Contractor advised to check site condition by themselves.
3. Can we make temporary accommodation at the site?
No
4. Can we use ground water from site for any concrete or masonry work?
Can be used, if the water condition is to the standard
5. Can we use local sand for Masonry works?
No
6. What is the distance from the Electric Main DB?
60ft
7. Is the project Lamp sum of Measure and Pay?
It is a lamp sum project.
8. What is the distance from the jetty to the site?
1500ft
9. Do we have to start the construction works together?
Yes

If any Discrepancies from the drawing or BOQ, include it in The Addition and Omission

