


New 9 Story Air Condition Outdoor Layout



- Total 30 Outdoor Units of 244 KW power (3 Phase 220/250V 50Hz)
- There should be a control Network system connecting indoor and outdoor units and between centralised control system and I/O units through H-LinkII
- Internal Data and fault diagnosis should be easily accessed by user through CS-NET and there should be a central station DX to access the network.
- In the extreme condition of 32 Deg Celcius and 80% RH, there is tendency of condensation on pipe surfaces. Therefore refrigerent pipe insulation thickness should be more than 30mm and sould be aluminium foiled to prevent condensation on the surface of the pipe