



1. ALL DIMENSIONS SHOWN ARE IN MILLIMETERS (MM),  
UNLESS OTHERWISE SHOWN
2. ALL LEVELS SHOWN ARE IN METERS.  
ALL LEVELS SHOWN ARE FROM MEAN SEA LEVEL
3. THIS DRAWING TO BE READ IN CONJUNCTION WITH ALL OTHER  
RELEVANT DRAWINGS, GENERAL NOTES AND SPECIFICATIONS.
4. ALL NON-PRESSURE PIPES SHALL BE UPVC TO ASTM D-3034  
SDR 35.
5. ALL GRAVITY NETWORK LINES SHALL BE 160mm DIA.
6. ALL GRAVITY NETWORK LINES SHALL HAVE MINIMUM 0.5% SLOPE.
7. ALL NON-PRESSURE PIPES SHALL HAVE RUBBER SEAL JOINT.
8. ALL LIFT STATIONS, MANHOLES AND CLEAN OUTS SHALL BE  
PLASTIC MOULDED TYPE.
9. CHAMBER FROM THE HOUSEHOLD TO THE INSPECTION  
CHAMBER IS OUT OF THIS CONTRACT.
10. PROVISION SHALL BE GIVEN IN IC FOR MULTIPLE CONNECTIONS.
11. THE PIPE DIMENSIONS REPRESENT IN OUTSIDE DIAMETER(O.D).

DESIGNED	DRAWN	CHECKED	APPROVED	SCALE	DATE
SK	JP	SS	MA	1:50	15.09.'15
PROJECT No.	SHEET No.	DRAWING No.			
K-619	1 OF 1	RH-SW-122			
REV. No.	1				