

- NOTES:-
1. ALL DIMENSIONS ARE IN MILLIMETERS EXCEPT AND OTHERWISE SPECIFIED.
 2. THIS DRAWING IS TO BE READ IN CONJUNCTION WITH ALL OTHER RELEVANT DRAWINGS AND SPECIFICATIONS.
 3. ALL ABOVE GROUND CONDUIT SHALL BE RIGID HOT DIP GALVANIZED EXCEPT AS NOTED.
 4. ALL NEMA 3R GASKETED S.S ENCLOSURES TO HAVE LOCKABLE HANDLE AND 3 POINT LATCHING.

REFERENCE DRAWINGS		
SL.No.	DRAWING No.	DESCRIPTION

..
..
..
..
0	17-09-15	DETAILED DESIGN SUBMISSION	BA	RDS	MA
REV.	DATE	DESCRIPTION	DRAWN	CHKD.	APPRD.

REVISION


CLIENT
MINISTRY OF ENVIRONMENT & ENERGY
REPUBLIC OF MALDIVES

CONSULTANT:
مكتب الحبشي للاستشارات الهندسية
Al-Habshi Consultants Office
Tel : 2430103 / 2433131 - Fax : 2431136
P.O.Box 27164 Safat 13132 - Kuwait


PROJECT:
Design and Supervision works for provision of
Water Supply Facilities in 4 islands and
Sewerage Facilities in 5 islands - Republic of Maldives

DRAWING TITLE:
TYPICAL LIFTING STATION DETAILS
GA.KOLAMAAFUSHI ISLAND

DESIGNED	DRAWN	CHECKED	APPROVED	SCALE	DATE
RDS	BA	RDS	MA	NTS	17-09-15
PROJECT No.	SHEET No.	DRAWING No.			
K-619	1 OF 1	KO-EL-101			
REV. No.	0				



TYPICAL LIFTING STATION LAYOUT



FRONT ELEVATION

SIDE VIEW

TYPICAL DETAIL FOR
DUPLEX PUMP CONTROL PANEL