



Ministry of Finance

Ameenee Magu, Male', Republic of Maldives Telephone: (960) 334 9266, Fax: (960) 332 0706 ב תרשם אין דור בתייחשם הבתיכב י בילי בנפק מרב

CLARIFICATION 1

المؤمرونا شاشر 1

سَرُسُوْهُ مِر No:	TES/2020/W-025		
Project:	Provision of Water Supply and Sewerage Facilities (Lot 1 to Lot 18)		
مُرُدُّ Issued Date	18 th March 2020		
جَوْرُدُّ رُوْرُ No. of Pages: -02	איר.איפ BoQ: -00	نگرزیژ Drawings: -00	

وِهُ رَمْرُودُورُ وِ وَسَوْتُ يَهِمُومُ عُهِمُ مِنْ رَمُرُودُونُ غَرِوَامِودُ مُنْ مُؤَمِّدُونُ عَرِوامُونُونُ عَمْ مِوامُونُونُ عَمْ مُؤمِّدُونُ اللهِ Please include this amendment when submitting the bid .

• Clarifications are given in the below table

#	Queries	Clarification
1	4.3 TECHNICAL SCHEDULES: Is it necessary to sign on this document?	The Bidder is required to fill the technical schedule provided under section 4.3
2	Please provide Technical specification of	The Sewage Treatment Plant should be designed for the estimated Peak Wet Weather Flow (PWWF) of 30 years, to achieve the following Effluent Standards;
	STP.	BOD₅ : 20 mg/L COD : 50 mg/L TSS: 30 mg/L
3	- Technical specification of Jetting machine differs with the recent specification revised by EPA. We would like to clarify which one to follow and quote.	Latest specifications should be used.
4	Is it single stage single envelope bid? In addition, please confirm whether the price bid will be opened on the same day of technical bid or at a later stage.	The bidding procedure is single stage single envelope. Bid prices will be read out on the same day, as specified under ITB 27
5	Population growth rates for islands since only 2017 population are given	The bidder is required to get this information on their own
6	Land use planes of the Islands	Provided
7	Are tenders supposed to priced for all three types of STP's	The bidders are required to price for all three type of STPs
8	Is this tender only for Local bidders? Can the re- registered (Maldives) foreign companies participate in this tender if so will the Bid Security from foreign country be accepted for the tender	Subjected project is only open for Local Companies



Page 1 of 2

<u> </u>	Highlighted islands already have the rainwater	
9	harvesting systems ongoing. So would we need	Price Schedules have been revised in light of the
	to incorporate the system or dismiss the existing system?	existing Rain water Harvesting Systems
10	Should the bidder submit the concept	Bidder is required to submit initial concept
	design report with the tender submission?	design as per the requirements set in Section
	Normally this will be after awarding the	4 Part C, subsection 4.2.1 Initial Conceptual
	project to the contractor.	design
11	Should the bidder submit the concept	The Bidder is not required to submit layouts of
	drawings with the layouts like sewerage,	sewerage network, rainwater network etc.
	water & rain water network with the tender	Concept Information which is required to be
	submission. Normally this will be after	submitted is provided under 4.2.1, Initial
	awarding the project to the contractor.	Conceptual design.
12	Should the bidder submit the land use plan	*
	with the tender submission? Land use plan	Bidder is not required to submit land use plan during bid submission
	is not updated for most the islands. This	
	process of making the land use plan is a	
	time consuming process. Normally this will	
	be after awarding the project to the	
	contractor.	
13	Please provide us the details of public roof	Bidder is required to gather this information
	where rain water can be collected.	on their own
14	Please provide us the population growth	Bidder is required to gather this information
	rate to be considered for 15 & 35 years.	on their own
	Please provide us the LPCD to be	15 year horizon - 50 LPCD35 year horizon - 75
	considered for 15 & 35 years to compute	LPCD
	the water table.	LI CD
	Please provide us the available spaces	Bidder may identify the available spaces from
15	which MLSA can approve for the suggested	the Land use plans. Where land use plan is not
	facilities like Pumping Station,	available the bidder may contact the island
	RO/Administration Building, STP etc.	councils to get this information
	1	

Name: Fathimath Rishfa Ahmed

Signature: