



## CLARIFICATION 1

1 ވަނަ ބަޔާން ދެއްވުން

ނަންބަރު No:	TES/2021/W-125		
ފޮޓޯ ނަންބަރު Project:	Construction of 06 Classroom at S. Atoll School (Sn. Hulhudhoo/Meedhoo)		
ދިނުމުގެ ތާރީޚު Issued Date	19 <sup>th</sup> September 2021		
ސަފުހާގެ ޖަދުވަލު No. of Pages: -01	ބޮޑުވަނަ Boq: -00	ވަނަ ބަޔާން Drawings: -00	

Please include this Clarification when submitting the bid

މި ބަޔާނު ހިމާނައިގެން ބަޔާން ދެއްވުމަށް ފަސޭހަވާނެ ގޮތަށް ހެއްދެވިފައިވާނެއެވެ.

➤ Below please find the clarifications for the queries.

1. Bill no: 2,2-1 Details of the demolition are and if there are any trees to cut or remove?  
No structures to demolish or trees to remove within the site.
2. Bill no: 13, 2-3 Length of Main electrical Cable from Fenaka DB?  
150ft.
3. Can we make storage and accommodation at site?  
Storage space available on site.  
Contractor to arrange own accommodation.
4. Can we use water from site for concrete and other works?  
Yes, there is a water well. Supply water is also available.

ނަންބަރު

Name: Fathimath Rishfa Ahmed

ސަފްޞަފާ

Signature: