



NOTES:-

1. ALL DIMENSIONS ARE IN MILLIMETRES AND ALL LEVELS AER IN METRES, UNLESS OTHERWISE NOTED.
2. DRAWINGS ARE NOT TO BE SCALED. ONLY WRITTEN DIMENSIONS ARE TO BE FOLLOWED.
3. ALL CONCRETE WORK SHALL BE DESIGN GRADE C30.
4. BLINDING CONCRETE WORK SHALL BE GRADE C10.
5. ALL STRUCTURE WORK SHALL CONFORM TO BS 7668. GRADE 46A/ASTMA36. ALL STRUCTURAL MEMBERS SHALL BE HOT DIP GALVANIZED AND PAINTED AS PER SPECIFICATIONS.
6. STEEL BARS DENOTED "T" SHALL BE HYSD BARS OF GRADE 460 CONFIRMING TO BS 4449
7. NET SBC OF 15T/SQM IS CONSIDERED IN THE DESIGN.
8. CLEAR COVER TO REINFORCEMENT
 - a. RAFT -50mm
 - b. WALL -50mm
 - c. SLAB -25mm

RAIN WATER LIFT WELL



PLAN VIEW



SECTION X1-X1



Vivek V. Pagnis

VIVEK V. PAGNIS
(STRUCTURAL ENGINEER)

TENDER PURPOSE

CLIENT				MINISTRY OF ENVIRONMENT AND ENERGY MALE, REPUBLIC OF MALDIVES			
PROJECT				PROVISION OF RAINWATER HARVESTING SYSTEM IN 10 ISLANDS			
ASSIGNMENT				CONSULTANCY SERVICES FOR DESIGN AND SUPERVISION OF RAINWATER HARVESTING SYSTEM IN SH. NOOMARA, SH. BLEHEFAHI, SH. FEYDHOO, SH. FEEVAHI, SH. NARUDHOO, SH. LHAIMAGU, SH. FUNADHOO, N. HENBADHOO, N. LHOHL, N. MAGOODHOO, MALDIVES [PACKAGE - 2]			
No.	DESCRIPTION	BY	DATE	APPR.	DRAWING TITLE		
REVISION					TYPICAL DRAWING OF LIFT WELL		
CONSULTANT				APPROVED			
SHAH TECHNICAL CONSULTANTS PVT. LTD., INDIA IN ASSOCIATION WITH				SSS	SSS	SPP	PDP
DEVELOPMENT TECHNOLOGIES MALDIVES, MALDIVES				SCALE	DATE	DRAWING NUMBER	REVISION
				AS SHOWN	FEB 2018	Sh.Feydhoo/WS/07	0