


STRUCTURAL SERIES					
	NO.	DRAWING TITLE	DWG NO.	REV.	REMARKS
01		DRAWING LIST	G-1.00	00	
02		GENERAL NOTES	G-1.01	00	
03		GROUND FLOOR PLAN	G-1.02	00	
04		ROOF PLAN	G-1.03	00	
05		ELEVATIONS A & B	G-1.04	00	
06		SECTION @ GRID 4	G-1.05	00	
07		COLUMN LOCATION PLAN	G-1.06	00	
08		FOUNDATION PLAN	G-1.07	00	
09		ROOF BRACING PLAN	G-1.08	00	
10		STRUCTURAL SECTION @ GRID A	G-1.09	00	
11		STRUCTURAL DETAILS 1	G-1.10	00	
12		STRUCTURAL DETAILS 2	G-1.11	00	
13		SERVICES DRAWINGS	G-1.12	00	

DRAWING LIST

SCALE NTS

DRAWING NUMBER KEY



BUILDING NUMBERS:

01 = HARBOUR
02 = GUARD HOUSE
03 = VEHICLE SHED EXTENSION BUILDING
04 = STORAGE EXTENSION BUILDING
05 = FUEL FARM
06 = WATER STORAGE TANKS
07 = MECHANICAL STORAGE
08A = POWER HOUSE
08B = DESALINATION BUILDING
09 = WASTE SORTING SHED EXTENSION
09A = SORTING SHED TO INCINERATOR SHADING

10. BUNKERS

10A - ADMIN TRAINING
10B - RECEIVING (NON-RECYCLING)
10C - RECEIVING (E-WASTE)
10D - RECEIVING (PLASTICS)
10E - RECEIVING (PAPER ITEMS)
10F - RECEIVING (REJECTS)
10G - RECEIVING (ORGANIC WASTE)
10H - RECEIVING (MEDICAL WASTE)
10I - RECEIVING (METALS)
10J - RECEIVING (NON-RECYCLING)
10K - RECEIVING (FOR EXPANSION)
10L - RECEIVING (FOR EXPANSION)

11. WASTE MANAGEMENT FACILITIES

11A - RESERVED FOR FUTURE USE
11B - RECYCLABLES
11C - RECYCLING (WITH COMPACTION AND BAILING PLANT)
11D = E-WASTE
11E = BULK WASTE
11F = COMPOST
11G = HAZARDOUS WASTE

12 = UNPROCESSED WASTE BUNKER

13 = PUMP HOUSE

14 = PROPOSED LANDFILL

14A = C&D WASTE
14B = GENERAL WASTE

DRAWING STAGES:

CN = CONCEPTUAL DESIGN
SD = SCHEMATIC DESIGN
DD = DESIGN DEVELOPMENT
CD = CONSTRUCTION DOCUMENTS

DISCIPLINE:

G = GENERAL
A = ARCHITECTURAL
S = STRUCTURAL
E = ELECTRICAL
P = PLUMBING
F = FIRE PROTECTION

DRAWING NUMBERS:

1 = GENERAL
2 = PLANS
3 = ELEVATIONS
4 = SECTIONS
5 = DETAILS
6 = SCHEDULES

PROJECT :

R. VANDHOO

**PROJECT: SOLID WASTE
MANAGEMENT FACILITY**

CLIENT : MINISTRY OF ENVIRONMENT AND ENERGY

CONSULTANT : **HUSSAIN SHAHEED**

DRAWN BY : ARIF

CHECKED BY : HUSSAIN SHAHEED

TITLE : AS GIVEN

SCALE : AS GIVEN DATE:19.01.2019

PG NO.

DWG NO: VAN-TD-03-G-1.00-R0

REV. NO: R0-190119/01

REV. NOTES

-
-
-
-
-

APPROVED BY:

APPROVED DATE:

GENERAL NOTES

GENERAL

1. THE CONTRACTOR IS REQUIRED TO SUBMIT COORDINATED M&E PENETRATION DRAWINGS FOR APPROVAL.
2. ALL STRUCTURAL DRAWINGS SHALL BE READ IN CONJUNCTION WITH ALL ARCHITECTURAL AND SERVICE DRAWINGS, SPECIFICATIONS AND WRITTEN INSTRUCTIONS IF ISSUED DURING THE COURSE OF THE CONTRACT. ALL DISCREPANCIES SHALL BE REFERRED FOR DECISION BEFORE PROCEEDING WITH THE WORK. IF A CONFLICT OCCURS BETWEEN GENERAL SPECIFICATIONS AND ANY OF THESE DRAWINGS, THE INDIVIDUAL DRAWINGS SHALL GOVERN.
3. THE DRAWINGS SHALL NOT BE SCALED. ALL DIMENSIONS RELEVANT TO SETTING OUT AND OFF-SITE SHALL BE VERIFIED BY THE CONTRACTOR BEFORE CONSTRUCTION AND FABRICATION IS COMMENCED.
4. DURING THE CONSTRUCTION PERIOD THE CONTRACTOR SHALL BE RESPONSIBLE TO MAINTAIN THE STABILITY OF STRUCTURE AND ENSURE THAT NO STRUCTURAL ELEMENT BE OVERSTRESSED UNDER CONSTRUCTION ACTIVITIES.
5. WORKMANSHIP AND MATERIALS SHALL BE IN ACCORDANCE WITH THE RELEVANT RECENT BS CODES OR OTHER ACCEPTABLE STANDARDS.
6. BASED ON THE DRAWINGS AND SPECIFICATIONS THE CONTRACTOR SHALL PRODUCE STRUCTURAL SHOP DRAWINGS FOR APPROVAL IF REQUESTED.
7. ALL DIMENSIONS TO STRUCTURAL DRAWINGS ARE IN MILLIMETERS UNLESS STATED OTHERWISE. ALL LEVELS ARE EXPRESSED IN METERS.
8. THE REINFORCED CONCRETE DESIGN IS BASED ON BS 8110 'STRUCTURAL USE OF CONCRETE'
9. REFER TO STANDARD AND TYPICAL DETAILS AS SHOWN IN THE TYPICAL DRAWINGS FOR DETAILS NOT SHOWN SPECIFICALLY.
10. ALL PROPS AND FRAMEWORK FOR BEAMS AND SLABS SHALL BE REMOVED BEFORE CONSTRUCTION OF ANY MASONRY WALLS OR OTHER PERMANENT LOADING ON THE SLAB.
11. ALL NON-LOAD BEARING WALLS SHALL BE KEPT CLEAR OFF THE UNDERSIDE OF SLABS AND BEAMS BY 30MM. THE JOINT SHALL BE FILLED WITH FIBRE BOARD OR COMPRESSIBLE MATERIAL PRESSED METAL COVERING BOTH SIDES OF THE JOINT, AND THE METAL COVERING SHALL BE FIXED TO SOFFIT OF THE BEAM OR SLAB AS THE CASE MAYBE.
12. THE CONTRACTOR IS REQUIRED TO SUBMIT A DRAWING SHOWING THE INTENDED SEQUENCE OF POURING, LOCATION AND DETAILS OF CONSTRUCTION JOINTS TO MINIMIZE THE POSSIBILITY OF OCCURRENCE OF SHRINKAGE CRACKS.
13. PRIOR TO COMMENCEMENT OF WORK THE CONTRACTOR SHALL SUBMIT THE FOLLOWING FOR THE APPROVAL BY THE EMPLOYER'S PERSONNEL:
 - 13.1. METHOD AND SEQUENCE OF CONSTRUCTION.
 - 13.2. DESIGN AND CALCULATION OF TEMPORARY SUPPORT TO EXCAVATION PREPARED AND APPROVED BY AN ACCREDITED GEOTECHNICAL ENGINEER.
 - 13.3. INSTRUMENTATION PROGRAMME TO MONITOR SOIL MOVEMENT, WATER TABLE AND SETTLEMENT.
 - 13.4. EFFECTS OF GROUND WATER LEVEL DRAW-DOWN.
 - 13.5. PRECAUTIONARY MEASURES TO AVOID DAMAGE TO NEIGHBORING BUILDING STRUCTURES.

FOUNDATIONS

1. ALL FOUNDATIONS HAS BEEN DESIGNED FOR SAFE GROUND PRESSURE OF 150 kN/m²
2. ALL BACKFILL SHOULD BE DONE WITH APPROVED MATERIAL AND SOURCE. ALL BACKFILL SHOULD BE STRUCTURAL FILL, COMPACTED IN LAYERS AS SPECIFIED.
3. WEAK POCKETS FOUND BELOW THE ASSUMED FOUNDATION LEVELS SHALL BE REMOVED AND REPLACED BY PLAIN CONCRETE.
4. IN CASE OF EXCAVATIONS BELOW THE ASSUMED LEVEL OF THE FOUNDATION, THE SOIL SHALL BE REPLACED BY PLAIN CONCRETE.
5. IN CASE GROUND WATER IS PRESENT ABOVE FOUNDATION LEVEL, THE CONTRACTOR SHALL BE RESPONSIBLE FOR DEWATERING THE SITE, AND LOWERING THE GROUND WATER TO AT LEAST 70 cm BELOW LEVEL OF FOUNDATIONS.
6. THE CONTRACTOR SHALL MAINTAIN DRY WORKING CONDITIONS THROUGHOUT THE CONSTRUCTION PERIOD. RESTORING WATER TABLE CAN BE DONE AFTER BACKFILLING AND COMPACTION UP TO THE SLAB ON GRADE LEVEL, OR AS DIRECTED BY THE ENGINEER.
7. NO BACK FILLING SHALL BE PLACED AGAINST WALLS RETAINING EARTH, UNLESS THE WALLS ACHIEVE SUFFICIENT STRENGTH TO PREVENT MOVEMENT OR STRUCTURAL DAMAGE.

CONCRETE

- CEMENT SHALL BE ORDINARY PORTLAND CEMENT TO BS 12.
2. CONCRETE GRADE:
 - 2.1. ALL IN-SITU STRUCTURAL CONCRETE SHALL HAVE MINIMUM 28 DAYS CUBE STRENGTH OF 30 N/mm² TO THE RELEVANT CLAUSES OF BS5328.
 - 2.2. ALL PLAIN CONCRETE (OR BLINDING) SHALL HAVE MINIMUM 28 DAYS CUBE STRENGTH OF 15 N/mm², TO THE RELEVANT CLAUSES OF BS5328.
3. AGGREGATES SHALL BE TO BS 882 WITH A NOMINAL SIZE OF 20 mm
4. SULPHATE RESISTING CEMENT SHALL BE USED FOR ALL CONCRETE IN CONTACT WITH GARBAGE.
5. NO OPENINGS, HOLES, CHASES OR EMBEDMENT OF PIPES OTHER THAN THOSE IN THE STRUCTURAL DRAWINGS SHALL BE MADE IN CONCRETE MEMBERS WITHOUT PRIOR APPROVAL.
6. CONSTRUCTION AND EXPANSION JOINTS SHALL BE PROPERLY FORMED AND USED ONLY WHERE SHOWN OR SPECIFICALLY APPROVED.
7. NO ELECTRICAL CONDUIT AND PIPES ARE TO BE CAST IN COLUMNS OR THROUGH BEAMS WITHOUT PRIOR APPROVAL UNLESS OTHERWISE SHOWN IN THE DRAWINGS.
8. OPENING IN SLABS:
 - 8.1. FOR OPENING LESS THAN 300 x 300 mm, BARS SHALL BE RE-ARRANGED AROUND THE OPENING.
 - 8.2. FOR OPENINGS GREATER THAN 300 x 300 mm BUT LESS THAN 450 x 450 mm AND NOT SHOWN ON PLAN, PROVIDE 2 DIA 12 TOP AND BOTTOM ALONG EACH SIDE AND T16 DIAGONALLY AT CORNERS OR AS OTHERWISE DETAILED. AMOUNT OF BARS DISCONTINUED DUE TO THE OPENING SHALL BE PLACED AT THE RESPECTIVE SIDES.
 - 8.3. OPENINGS GREATER THAN 450 x 450 mm AND NOT SHOWN ON PLAN SHALL BE APPROVED.
9. SHEAR KEY SHALL BE PROVIDED AT ALL CONSTRUCTION JOINTS.
10. WATERPROOFING SYSTEM AS SPECIFIED IN THE SPECIFICATIONS SHALL BE USED IN STRUCTURAL ELEMENTS WHICH ARE CONTINUOUSLY IN CONTACT WITH SOIL OR WATER ON LIFT PIT, ROOF SLAB, R.C. RETAINING WALL AND RAFT ETC.
11. TO PROVIDE INTEGRAL SEALING BETWEEN CONCRETE CAST IN-SITU IN SEPARATE POUR, APPROVED WATERSTOP HAS TO BE INSTALLED FOR ALL CONSTRUCTION JOINTS IN CONTACT WITH WATER AND SOIL.
12. SPECIAL RULES REGARDING CONCRETING IN HOT WEATHER SHALL BE OBSERVED.


REINFORCEMENT

1. HIGH STRENGTH DEFORMED BARS DENOTED T SHALL CONFORM TO BS-4449 WITH MINIMUM YIELD STRENGTH $F_y = 460 \text{ N/mm}^2$, MILD STEEL DENOTED R SHALL HAVE 250 N/mm^2 YIELD STRENGTH. WELDED WIRE MESH SHALL COMPLY WITH BS-4483.
2. SPLICES IN REINFORCEMENT SHALL BE MADE ONLY IN THE POSITION SHOWN OR AS OTHERWISE APPROVED.
3. SPACER BARS SHALL BE PROVIDED AT 100cm CENTERS WHEREVER REINFORCEMENT IS PLACED IN MORE THAN ONE LAYER, UNLESS STATED OTHERWISE.
4. WELDING OF REINFORCEMENT SHALL NOT BE PERMITTED. IF REINFORCEMENT SHOULD BE WELDED, APPROVAL IS REQUIRED.
5. ALL REINFORCEMENT SHALL BE SUPPORTED IN ITS CORRECT POSITION DURING CONCRETING BY APPROVED BAR CHAIRS, SPACERS, OR SUPPORT BARS.
6. TYPICAL DEVELOPMENT AND SPLICES OF DEFORMED BARS WITH $F_y = 460 \text{ N/mm}^2$ AND $F_{cu} = 30 \text{ N/mm}^2$, (CUBE STRENGTH) SHALL BE AS FOLLOWS, UNLESS OTHERWISE MENTIONED IN DRAWINGS:
 - 6.1. BASIC TENSION DEVELOPMENT LENGTH, $LD = 56 \times \text{BAR DIA}$
 - 6.2. MINIMUM COMPRESSION DEVELOPMENT LENGTH, $LDC = 40 \times \text{BAR DIA}$ (OR 300mm WHICH EVER IS MORE)
7. BENDING OF REINFORCEMENTS SHALL BE IN ACCORDANCE WITH BS 4466.

ABBREVIATIONS

APPROX	-APPROXIMATE
B	-BEAM
B.W.	-BOTH WAYS
BOT OR BTM	-BOTTOM
BOB	-BOTTOM OF BASE
BOS	-BOTTOM OF STEEL
BOT	-BOTTOM OF TRUSS
(B1)	-BOTTOM STEEL BOTTOM REINFORCEMENT
(B2)	-BOTTOM STEEL TOP REINFORCEMENT
BLDG	-BUILDING
ℓ	-CENTER LINE
C/C	-CENTER TO CENTER
C	-COLUMN
CO-ORD	-CO-ORDINATE
DPC	-DAMP PROOF COURSE
DET OR DTL	-DETAIL
DIA	-DIAMETER
D/B	-DISTRIBUTION BAR
DWG	-DRAWING
EF	-EACH FACE
EW	-EACH WAY
EL	-ELEVATION (HEIGHT)
ELEV	-ELEVATION (VIEW)
FF	-FAR FACE
FS	-FAR SIDE
FW	-FILLET WELD
FFL	-FINISHED FLOOR LEVEL
FDN OR FND	-FOUNDATION
FB	-FOUNDATION BEAM
GA	-GENERAL ARRANGEMENT
G.I.	-GALVANIZED IRON
IL	-INVERT LEVEL
LG	-LONG OR LENGTH
MAX	-MAXIMUM
MKD	-MARKED
MIN	-MINIMUM
MISC	-MISCELLANEOUS
N/F	-NEAR FACE
N/S	-NEAR SIDE
NOM	-NOMINAL
NTS	-NOT TO SCALE
Nos	-NUMBERS
O/D	-OUTSIDE DIAMETER
PL	-PAVEMENT LEVEL
PROJ	-PROJECTION
QTY	-QUANTITY
RAD	-RADIUS
R.C.	-REINFORCED CONCRETE
REQ'D	-REQUIRED
SW	-SHEAR WALL
STIFF	-STIFFENER
SQ	-SQUARE
SFL	-STRUCTURAL FINISH LEVEL
THK	-THICK (NESS)
TEMP	-TEMPORARY
TOB	-TOP OF BEAM
TOC	-TOP OF COLUMN
TOG	-TOP OF GROUT
TO Platf	-TOP OF PLATFORM
TS	-TOP OF SLAB
TOS	-TOP OF STEEL
TOT	-TOP OF TRUSS
TYP	-TYPICAL
U/S	-UNDERSIDE
UNO	-UNLESS NOTED OTHERWISE
(T1)	-TOP STEEL TOP REINFORCEMENT
(T2)	-TOP STEEL BOTTOM REINFORCEMENT
(UPB)	-UPSTAND BEAM

PROJECT : R. VANDHOO PROJECT: SOLID WASTE MANAGEMENT FACILITY	DRAWN BY : ARIF	DWG NO: VAN-TD-03-G-1.01-R0	APPROVED BY:
	CHECKED BY : HUSSAIN SHAHEED	REV. NO: R0-190119/01 REV. NOTES	
CLIENT : MINISTRY OF ENVIRONMENT AND ENERGY	TITLE : AS GIVEN	-	
	SCALE : AS GIVEN DATE:19.01.2019	-	
CONSULTANT : HUSSAIN SHAHEED	PG NO.	-	APPROVED DATE:
		-	




GROUND FLOOR PLAN

SCALE 1:100



NOTE:
ALL UNITS IN MM

PROJECT : R. VANDHOO PROJECT: SOLID WASTE MANAGEMENT FACILITY CLIENT : MINISTRY OF ENVIRONMENT AND ENERGY CONSULTANT : HUSSAIN SHAHEED	DRAWN BY : ARIF	DWG NO: VAN-TD-03-G-1.02-R0	APPROVED BY: APPROVED DATE:
	CHECKED BY : HUSSAIN SHAHEED	REV. NO: R0-190119/01	
	TITLE : AS GIVEN	REV. NOTES	
	SCALE : AS GIVEN	-	
	DATE:19.01.2019	-	
	PG NO.	-	



ROOF PLAN

SCALE 1:100



NOTE:
ALL UNITS IN MM


PROJECT :
R. VANDHOO
PROJECT: SOLID WASTE
MANAGEMENT FACILITY
CLIENT : MINISTRY OF ENVIRONMENT AND ENERGY
CONSULTANT : **HUSSAIN SHAHEED**

DRAWN BY : ARIF
CHECKED BY : HUSSAIN SHAHEED
TITLE : AS GIVEN
SCALE : AS GIVEN
DATE:19.01.2019
PG NO.

DWG NO: VAN-TD-03-G-1.03-R0
REV. NO: R0-190119/01
REV. NOTES
-
-
-
-
-

APPROVED BY:

APPROVED DATE:




ELEVATION A

SCALE 1:100



NOTE:
ALL UNITS IN MM



ELEVATION B

SCALE 1:100




NOTE:
ALL UNITS IN MM

<div>PROJECT : R. VANDHOO PROJECT: SOLID WASTE MANAGEMENT FACILITY</div> <div>CLIENT : MINISTRY OF ENVIRONMENT AND ENERGY</div> <div>CONSULTANT : HUSSAIN SHAHEED</div>	<div>DRAWN BY : ARIF</div> <div>CHECKED BY : HUSSAIN SHAHEED</div> <div>TITLE : AS GIVEN</div> <div>SCALE : AS GIVEN</div> <div>DATE:19.01.2019</div>		<div>DWG NO: VAN-TD-03-G-1.04-R0</div> <div>REV. NO: R0-190119/01</div> <div>REV. NOTES</div> <div>-</div> <div>-</div> <div>-</div> <div>-</div> <div>-</div> <div>-</div>	<div>APPROVED BY:</div> <div></div>
	<div>PG NO.</div>		<div>APPROVED DATE:</div>	

STRUCTURAL NOTES:
STEEL STRENGTHS USED IN DESIGN OF PORTAL FRAME

RAFTERS	460UB 67.1	yield stress	310 MPa
COLUMNS	460UB 67.1	yield stress	310 MPa
END WALL COLUMNS	350 UB	yield stress	310 MPa
ROOF BRACING MEMBERS	90 x 90 x 6 EA	yield stress	320 MPa
WALL BRACING MEMBERS	75 x 75 x 5 EA	yield stress	320 MPa
STRUTS	114 x 4.5 CHS	yield stress	250 MPa
* ALL TRUSS MEMBERS AND PLATES IN CONNECTIONS SHALL HAVE A YIELD STRENGTH OF 250MPa			
* ALL BOLTS SHALL HAVE TENSILE STRENGTH OF 830 MPa			
* ALL WELDS SHALL HAVE A NOMINAL TENSILE STRENGTH 480 MPa			
* MATERIAL EXPOSURE GRADE: BS SEVERE WEATHER CATEGORY			

NOTE:
PURLINS SPACED AT 1200 C/C
GRITS SPACES AT 1700 C/C
FB = FLY BRACE (SEE FLY BRACE DETAIL)




STRUCTURAL SECTION @ GRID 4

SCALE 1:100

0 1 2 3 4 5

NOTE:
ALL UNITS IN MM

PROJECT : R. VANDHOO PROJECT: SOLID WASTE MANAGEMENT FACILITY CLIENT : MINISTRY OF ENVIRONMENT AND ENERGY CONSULTANT : HUSSAIN SHAHEED	DRAWN BY : ARIF		DWG NO: VAN-TD-03-G-1.05-R0 REV. NO: R0-190119/01 REV. NOTES - - - - - - - -	APPROVED BY: APPROVED DATE:
	CHECKED BY : HUSSAIN SHAHEED			
	TITLE : AS GIVEN			
	SCALE : AS GIVEN	DATE:19.01.2019		
	PG NO.			



COLUMN LOCATION PLAN

SCALE 1:100



NOTE:
ALL UNITS IN MM


PROJECT :
R. VANDHOO
PROJECT: SOLID WASTE
MANAGEMENT FACILITY
CLIENT : MINISTRY OF ENVIRONMENT AND ENERGY
CONSULTANT : **HUSSAIN SHAHEED**

DRAWN BY : ARIF
CHECKED BY : HUSSAIN SHAHEED
TITLE : AS GIVEN
SCALE : AS GIVEN
DATE:19.01.2019
PG NO.

DWG NO: VAN-TD-03-G-1.06-R0
REV. NO: R0-190119/01
REV. NOTES
-
-
-
-
-


APPROVED BY:

APPROVED DATE:



FOUNDATION PLAN

SCALE 1:100



NOTE:
ALL UNITS IN MM


PROJECT :
R. VANDHOO
PROJECT: SOLID WASTE
MANAGEMENT FACILITY
CLIENT : MINISTRY OF ENVIRONMENT AND ENERGY
CONSULTANT : **HUSSAIN SHAHEED**

DRAWN BY : ARIF
CHECKED BY : HUSSAIN SHAHEED
TITLE : AS GIVEN
SCALE : AS GIVEN
DATE:19.01.2019
PG NO.

DWG NO: VAN-TD-03-G-1.07-R0
REV. NO: R0-190119/01
REV. NOTES
-
-
-
-
-


APPROVED BY:

APPROVED DATE:



ROOF BRACING PLAN

SCALE 1:100



NOTE:
ALL UNITS IN MM


PROJECT :
R. VANDHOO
PROJECT: SOLID WASTE
MANAGEMENT FACILITY
CLIENT : MINISTRY OF ENVIRONMENT AND ENERGY
CONSULTANT : **HUSSAIN SHAHEED**

DRAWN BY : ARIF
CHECKED BY : HUSSAIN SHAHEED
TITLE : AS GIVEN
SCALE : AS GIVEN
DATE:19.01.2019
PG NO.

DWG NO: VAN-TD-03-G-1.08-R0
REV. NO: R0-190119/01
REV. NOTES
-
-
-
-
-

APPROVED BY:

APPROVED DATE:



STRUCTURAL SECTION @ GRID A

SCALE 1:100



NOTE:
ALL UNITS IN MM


PROJECT :
R. VANDHOO
PROJECT: SOLID WASTE
MANAGEMENT FACILITY
CLIENT : MINISTRY OF ENVIRONMENT AND ENERGY
CONSULTANT : **HUSSAIN SHAHEED**

DRAWN BY : ARIF
CHECKED BY : HUSSAIN SHAHEED
TITLE : AS GIVEN
SCALE : AS GIVEN
DATE:19.01.2019
PG NO.


DWG NO: VAN-TD-03-G-1.09-R0
REV. NO: R0-190119/01
REV. NOTES
-
-
-
-
-

APPROVED BY:


APPROVED DATE:



FOUNDATION PAD 'F1' - SECTION
SCALE 1:20




FOUNDATION PAD 'F1' - PLAN
SCALE 1:20




**DETAIL A - GROUND SLAB
AT PERIMETER EDGE**

SCALE 1:20



COLUMN PEDESTAL DETAIL
SCALE 1:20




COLUMN BASEPLATE DETAIL
SCALE 1:20

NOTES:

STEEL STRENGTHS USED IN DESIGN OF PORTAL FRAME

RAFTERS	460UB 67.1	yield stress	310 MPa
COLUMNS	460UB 67.1	yield stress	310 MPa
END WALL COLUMNS	350 UB	yield stress	310 MPa
ROOF BRACING MEMBERS	90 x 90 x 6 EA	yield stress	320 MPa
WALL BRACING MEMBERS	75 x 75 x 5 EA	yield stress	320 MPa
STRUTS	114 x 4.5 CHS	yield stress	250 MPa
* ALL TRUSS MEMBERS AND PLATES IN CONNECTIONS SHALL HAVE A YIELD STRENGTH OF 250MPa			
* ALL BOLTS SHALL HAVE TENSILE STRENGTH OF 830 MPa			
* ALL WELDS SHALL HAVE A NOMINAL TENSILE STRENGTH 480 MPa			



GUTTER FIXING DETAIL


PROJECT :
R. VANDHOO
**PROJECT: SOLID WASTE
MANAGEMENT FACILITY**
CLIENT : MINISTRY OF ENVIRONMENT AND ENERGY
CONSULTANT : **HUSSAIN SHAHEED**

DRAWN BY : ARIF
CHECKED BY : HUSSAIN SHAHEED
TITLE : AS GIVEN
SCALE : AS GIVEN
DATE:19.01.2019
PG NO.








DWG NO: VAN-TD-03-G-1.10-R0
REV. NO: R0-190119/01
REV. NOTES
-
-
-
-
-

APPROVED BY:


APPROVED DATE:



KNEE CONNECTION



PROJECT : R. VANDHOO PROJECT: SOLID WASTE MANAGEMENT FACILITY CLIENT : MINISTRY OF ENVIRONMENT AND ENERGY CONSULTANT : HUSSAIN SHAHEED	DRAWN BY : ARIF CHECKED BY : HUSSAIN SHAHEED TITLE : AS GIVEN SCALE : AS GIVEN DATE: 19.01.2019 PG NO.	DWG NO: VAN-TD-03-G-1.11-R0 REV. NO: R0-190119/01 REV. NOTES - - - - -	APPROVED BY: APPROVED DATE:



LEGEND - ELECTRICAL

SYMBOL	DESCRIPTION
	INHOUSE DISTRIBUTION BOARD
	MAIN DISTRIBUTION BOARD
	FAN CONTROLLER
	2WAY SWITCH SINGLE GANG (UOS)
	1WAY SWITCH SINGLE GANG
	13A X 1G POWER SOCKET @ 300 FFL (UOS)
	13A X 2G POWER SOCKET @ 300 FFL (UOS)
	15A X 1G POWER SOCKET @ CEILING LEVEL
	DATA SOCKET (RJ45) @ 300 FFL (UOS)
	TELEPHONE COCKET (RJ11) @ 300 FFL (UOS)
	TV SOCKET (RF) @ 300 FFL (UOS)
	WALL MOUNTED LIGHT FITTING
	CEILING MOUNTED LIGHT FITTING
	CF TUBE LIGHT (4')
	CF TUBE LIGHT (4')
	EMERGENCY LIGHT (2HR)
	CEILING FAN
	AC UNIT
	EXHAUST FAN
	EXIT SIGN
	FIRE EXTINGUISHER - WATER
	FIRE EXTINGUISHER - DRY POWDER
	FIRE EXTINGUISHER - CO2
	WATER SPRINKLER WITH IONIZATION SMOKE DETECTOR

GENERAL NOTE:

*UOS - UNLESS OTHERWISE STATED

- ALL TOILET EXHAUSTS SHALL BE CONNECTED TO TOILET LIGHT SWITCHES

PROJECT :
R. VANDHOO
PROJECT: SOLID WASTE
MANAGEMENT FACILITY
CLIENT : MINISTRY OF ENVIRONMENT AND ENERGY
CONSULTANT : **HUSSAIN SHAHEED**

DRAWN BY : ARIF
CHECKED BY : HUSSAIN SHAHEED
TITLE : AS GIVEN
SCALE : AS GIVEN
DATE:19.01.2019
PG NO.

DWG NO: VAN-TD-03-G-1.12-R0
REV. NO: R0-190119/01
REV. NOTES
-
-
-
-
-

APPROVED BY:

APPROVED DATE: