



**AMENDMENT 2**

ފަހުގެ އިތުރުކުރުމުގެ 2

ނަންބަރު No:	TES/2016/W-115	
ފަހުގެ އިތުރުކުރުމުގެ Project:	Provision of Water Supply Facilities in B. Eydhafushi and Th. Vilufushi ( Re-tender)	
ދިނުމުގެ Issued Date	9 <sup>th</sup> November 2016	
ސަފުހާގެ އަދަދު No. of Pages: -2	ބޯޅު Boq: -00	ވަނަވަނަ Drawings: -00

Please include this amendment when submitting the bid. ފަހުގެ އިތުރުކުރުމުގެ 2 ފަހުގެ އިތުރުކުރުމުގެ 2 ފަހުގެ އިތުރުކުރުމުގެ 2 ފަހުގެ އިތުރުކުރުމުގެ 2 ފަހުގެ އިތުރުކުރުމުގެ 2

Please find attached answers to the queries raised for the subjected project

Please be informed that the bid submission for the project will be held on **15<sup>th</sup> November 2016 at 1100hrs local time.**

ނަންބަރު  
Name: Aminath Juweriya

ސަފުހާ  
Signature:



**Clarification**

**Provision of Water Supply Facilities in Th.Vilufushi and B.Eydhafushi.**

- Refer to the tender amendment No 1 dated November 2, 2016 downloaded from your website today .
  - In the said amendment at S.N 3 your answer to the query as reproduced hereunder:
  - “The Generator set / Power plant is now removed from the scope. therefore this is not applicable now.”
  - I would request you to kindly advise that whether as per said amendment no 1, under the head “Emergency Standby Power System” of the tender documents, following items should be removed.

<b><u>Emergency Standby Power System</u></b>		
Supply, install, connect and commission automatic mains failure standby diesel generating set rated 200kVA rating at 0.8 P.F., 50 Hz, 415 Volt complete with diesel engines, generator control panel, batteries, starter, motors, exhaust piping, silencers, 8 hrs built-in base daily fuel tank, vibration isolators, earthing, standard spares, tools, etc., all as shown on the drawings, as specified and as required for proper operation	1	No.
<b><u>ELECTRICAL WORK (contd..)</u></b>		
Supply, install and connect the 350A, 4 Pole Automatic Transfer Switch (ATS) panel with manual - double bypass - isolation complete with all necessary protection, measuring instruments, accessories interconnection, indicator lamps, etc., all as shown on the drawings, as specified and as required for proper operation	1	No.
Supply, install and connect the 200A, 4 Pole Automatic Transfer Switch (ATS) panel with manual - double bypass - isolation complete with all necessary protection, measuring instruments, accessories interconnection, indicator lamps, etc., all as shown on the drawings, as specified and as required for proper operation	1	No.
Testing and commissioning of the completed installations	Item	

2. We also request you to kindly send us the revised BOQ enable us to prepare our Bid accordingly.

**Ans 1 & 2 : With the removal of the backup generator system from the scope, the first three items stated in the table shall not be quoted. However since the Testing and commissioning is for the whole system, it has to be priced in the BOQ.**

