



AMENDMENT 3

މުޢަޞްސަޞާ 3

ނަންބަރު No:	TES/2018/W-04	
ފޮޓޯގްރާމް Project:	Establishment of a Drainage System – N.Holhudhoo	
ދިނުމުގެ ދުވަސް Issued Date	26 <sup>th</sup> March 2018	
ސަފުހާގެ އަދަދު No. of Pages: -02	ފޮޓޯގްރާމް Boq: -01	ޖަހާފައިވާ ވަނަވަތް Drawings: -01

Please include this amendment when submitting the bid . ފޮޓޯގްރާމް ޖަހާފައިވާ ވަނަވަތް ފޮޓޯގްރާމް ޖަހާފައިވާ ވަނަވަތް ފޮޓޯގްރާމް ޖަހާފައިވާ ވަނަވަތް

- Find the attached Clarification 1
- Revised BOQ and additional drawings are enclosed with this amendment

Please be informed that the **bid opening** for the project will be held on **Tuesday, 3<sup>rd</sup> April 2018, 1000hrs** at Ministry of Finance and Treasury, National Tender's Meeting Room.

ނަންމު  
Name: Fathimath Rishfa Ahmed

ސަފްޔާ  
Signature:



## Establishment of a Drainage System – N.Holhudhoo

### Clarification – 1

**1. Please confirm this measuring and pay or Lump sum contact?**

Yes it is a Lump sum project as informed in the clarification meeting

**2. Please provide details design drawing for sea outfall**

Please refer to the additional drawings

**3. BOQ does not have limit**

Please refer to the revised BOQ

**4. Drainage inlet detail drawing is missing**

Refer to the additional drawings

**5. Dry pump room detail drawings not provided**

The existing pump room in women's development committee plot will be used for dry pump room where both pumps and control panel will be located

**6. Minimum requirement list on tools and equipment shall require to Cost this item.**

Refer to the revised BOQ. This item is removed

**7. Provision sum BOQ has Maximum MVR 200,000.00, would like to know the which part of General works.**

Provisional sum is revised to include both bills. It is not specific to a single item in the BOQ and can be utilized based on requirements and approval by the client. However the limit of Provisional sum will be capped at MVR 400,000.00.

**8. Please provide pump panel board details, electrical reading meter details.**

Refer to the additional drawings

**9. Pump panel board and installation stand details not shown in the drawing.**

Refer to the additional drawings

