



CLARIFICATION 4

4 ވަނަ ޕްރޮޖެކްޓް ޕްލާން ސަފުހާ

ނަންބަރު No:	TES/2026/G-003	
ޕްރޮޖެކްޓް ނަންބަރު Project:	Design, Supply, and Installation of Radar System — including Civil Works for the Radar Tower Building, Training, and Maintenance and Repair Services	
ޖުމްހޫރިއްޔާ Issued Date	13th May 2026	
ސަފުހާ ގެ ޕޭޖް ގެ އަދަދު No. of Pages: -02	ޕްރޮޖެކްޓް ގެ ބޯޕްރިޔާ ގެ އަދަދު BoQ: -00	ޕްލާން ގެ އަދަދު Drawings: -00

Please include this sheet when submitting the bid. ބިދު ހުށަހަޅާ ފަހަރު މި ޕޭޖް ހިމާރުކޮށްގެން ހުށަހަޅާށެވެ.

- Please find attached, Clarification 04 for the project.

ނަންމު

Name: Aminath Naheen Ahmed

ސަފްދާ

Signature:



Clarification 4

1	Please specify the Height of the Radar Building.	The maximum height of the Radar Building shall not exceed 24m, including the Radome.
2	Please provide us number of floors required in the building.	Refer Section 6, Table 2 of the bid document. Radar equipment room shall have a clear height for installation and maintenance of equipment.
3	In "G01-Section 6" document page no 36 Figure 3, it is mentioned Radar plot as 2500sqft, will there be any additional area provided for Scaffolding, during assembly of Radome?	This can be arranged.
4	We respectfully request a extension for the bid submission deadline until 29 May 2026.	No further extension will be given.

