



LEGEND:-

SYMBOL	DESCRIPTION	QUANTITY
—	EXISTING Cable	-
---	PROPOSED 35sq.mm Cu/XLPE/SWA/PVC Cable	55m
---	PROPOSED 50sq.mm Cu/XLPE/SWA/PVC Cable	50m
D/B	EXISTING DISTRIBUTION BOX	-
D/B	EXISTING DISTRIBUTION BOX TO BE REPLACED	1 No.

NOTES:-

1. THESE DRAWINGS ARE PRELIMINARY AND ARE FOR TENDERING PURPOSES ONLY.
2. CONTRACTOR SHALL CARRY OUT DETAILED SITE SURVEY AND ENGINEERING / STUDY TO EVALUATE AND PROPOSE THE EXTENT OF REPLACEMENT / MODIFICATION REQUIRED IN THE EXISTING DISTRIBUTION NETWORK. THIS IS SUBJECT TO REVIEW AND APPROVAL BY THE EMPLOYER DURING THE ENGINEERING PHASE OF THE PROJECT.

PURPOSE OF SUBMISSION	REV	AUTHORISED BY	DATE	DRAWING TITLE	DESIGN : ESM	SCALE : N.T.S
FIRST REVISION	A	SWK	18/07/16	NETWORK DIAGRAM FOR D14-FODHDHOO	DRAWN : DAI	DRW NO. : J431-GOPA-038-GR-E-D-0001-REV.B
	B	A.M	20/12/16	PROJECT	LICENCE NO:	ISLAND NAME : FODHDHOO
				PREPARING OUTER ISLANDS SUSTAINABLE DEVELOPMENT	CLIENT: GOVERNMENT OF THE REPUBLIC OF MALDIVES	DATE: : 18JULY16
						PAGE : 1/1