



LEGEND:-

SYMBOL	DESCRIPTION	QUANTITY
---	PROPOSED 35sq.mm Cu/XLPE/SWA/PVC Cable	35m
---	PROPOSED 120sq.mm Cu/XLPE/SWA/PVC Cable	360m
---	EXISTING Cable	-
D/B	EXISTING DISTRIBUTION BOX	-
D/B	PROPOSED DISTRIBUTION BOX	-
D/B	EXISTING DISTRIBUTION BOX TO BE REPLACED	1 Nos

**NOTES:-**

1. THESE DRAWINGS ARE PRELIMINARY AND ARE FOR TENDERING PURPOSES ONLY.
2. CONTRACTOR SHALL CARRY OUT DETAILED SITE SURVEY AND ENGINEERING / STUDY TO EVALUATE AND PROPOSE THE EXTENT OF REPLACEMENT / MODIFICATION REQUIRED IN THE EXISTING DISTRIBUTION NETWORK. THIS IS SUBJECT TO REVIEW AND APPROVAL BY THE EMPLOYER DURING THE ENGINEERING PHASE OF THE PROJECT.

	PURPOSE OF SUBMISSION	REV	AUTHORISED BY	DATE	DRAWING TITLE NETWORK DIAGRAM FOR D07-LANDHOO	DESIGN : ESM	SCALE : N.T.S
	FIRST REVISION	A	SWK	18/07/16		DRAWN : DAI	DRW NO. : J431-GOPA-063-GR-E-D-0001-REV.B
		B	A.M	20/12/16	PROJECT PREPARING OUTER ISLANDS SUSTAINABLE DEVELOPMENT	LICENCE NO:	ISLAND NAME : LANDHOO
					CLIENT: GOVERNMENT OF THE REPUBLIC OF MALDIVES	DATE: : 18JULY16	PAGE : 1/1