


D15-VELIDHOO

POWER HOUSE MAIN LV DISTRIBUTION BOARD



LEGEND:-

SYMBOL	DESCRIPTION	QUANTITY
—	EXISTING Cable	-
---	PROPOSED 50sq.mm Cu/XLPE/SWA/PVC Cable	75m
---	PROPOSED 120sq.mm Cu/XLPE/SWA/PVC Cable	397m
D/B	EXISTING DISTRIBUTION BOX	-
D/B	EXISTING DISTRIBUTION BOX TO BE REPLACED	4 Nos.
D/B	EXISTING DISTRIBUTION BOX TO BE MODIFIED	-

NOTES:-

- THESE DRAWINGS ARE PRELIMINARY AND ARE FOR TENDERING PURPOSES ONLY.
- CONTRACTOR SHALL CARRY OUT DETAILED SITE SURVEY AND ENGINEERING / STUDY TO EVALUATE AND PROPOSE THE EXTENT OF REPLACEMENT / MODIFICATION REQUIRED IN THE EXISTING DISTRIBUTION NETWORK. THIS IS SUBJECT TO REVIEW AND APPROVAL BY THE EMPLOYER DURING THE ENGINEERING PHASE OF THE PROJECT.

PURPOSE OF SUBMISSION	REV	AUTHORISED BY	DATE	DRAWING TITLE	DESIGN	SCALE
FIRST REVISION	A	SWK	18/07/16	NETWORK DIAGRAM FOR D15-VELIDHOO	: ESM	: N.T.S
	B	A.M	20/12/16	PROJECT	DRAWN	DRW NO.
				PREPARING OUTER ISLANDS SUSTAINABLE DEVELOPMENT	: DAI	: J431-GOPA-092-GR-E-D-0001-REV.B
				CLIENT:	LICENCE NO:	ISLAND NAME
				GOVERNMENT OF THE REPUBLIC OF MALDIVES	: 18JULY16	: VELIDHOO
					DATE	PAGE
					: 18JULY16	: 1/1