

## CLARIFICATION 1

1 لا خَيْرَ فِيهِمْ لَا شَرَّ

<b>Pkg. No:</b> ٢٠١٦/٢٠١٦	<b>PSIP/2016/T1</b>		
<b>Issued Date:</b> ٢٠١٦/٢٠١٦	22 <sup>nd</sup> June 2016		
<b>Project:</b> ٢٠١٦/٢٠١٦	TES/2016/W-55 Construction of S.Hithadhoo Magistrate court TES/2016/W-54 Construction of fire station at S.Hulhumeedhoo		
<b>Deadline for submission:</b> ٢٠١٦/٢٠١٦	4 <sup>th</sup> July 2016 at 11:00hrs		
<b>No. of Pages:</b> ٢٠١٦/٢٠١٦	<b>BOQ:</b> ٢٠١٦/٢٠١٦	<b>Drawings:</b> ٢٠١٦/٢٠١٦	<b>Soft Copy:</b> ٢٠١٦/٢٠١٦
-02	-01	-00	-00

Please include this clarification when submitting the bid.

٢٠١٩

➤ Please find the below Answers for queries raised in the Clarification period.

**PROJECT: S.HITHADHOO MAGISTRATE COURT**

- **B.o.Q** for this project has been revised. **B.o.Q** will be emailed with Clarification and will be uploaded to the website.
- Q. Please confirm if manufactured rock sand can be used for structural Concrete works**
- A. Manufactured rock sand can be used for concrete works
- Q. Can we use local sand of Block making**
- A. Can be used if the assurance is given that the sand is free from chloride or any such contents that affects the strength of the block.
- Q. Please confirm whether temporary Electricity & water can be obtained from site**
- A. No Services (Electricity or Water) is available at the site
- Q. Kindly provide Air-condition Brand and BTU detail**
- A. Refer the Revised BOQ and annex 1 attached.
- Q. Kindly provide Ramp S. S. Pipe railing**
- A. Refer to the drawing Architectural Details
- Q. Kindly provide Boundary wall foundation Beam and capping Beam reinforcement details**
- A. Refer to the drawing of Structural Details
- Q. Kindly provide planter wall reinforcement details**
- A. Refer to the drawing of Structural Details
- Q. Boundary wall fencing - S. S. pipe Fencing is shown in drawing and B.o.Q, since it is 292 m can propose for G. I. pipe fencing, kindly clarify**
- A. Provide G I Pipe



**Q. Kindly provide the Distance from the Electrical Main DB**

A. Estimated to be within the range of 200 feet

**Q. Kindly provide AUTO CAD Drawing**

A. Drawing to be given only after the contract is awarded.

**PROJECT: TWO STOREY FIRESTATION AT S.MEEDHOO**

➤ Pictures of the Location is attached to this amendment.

**Q. Please provide the existing soil, site condition and demolition of any building, trees need to be cut or transported.**

A. Vacant lot; no demolition required; sandy undulated ground with grass growth and few trees at middle of plot that needs to be cut.

**Q. Ground water can be used for construction.**

A. Ground water can be used only if it is potable.

**Q. Please clarify the availability of material storage and accommodation within the site premises.**

A. Accommodation and storage can be setup within the site premises.

**Q. Please confirm whether temporary electricity & water can be obtained from site**

A. Temporary facilities cannot be provided and is the responsibility of the contractor. Outdoor distribution box is close to the premises and as for water; a ground water well can be used temporarily.

**Q. Please provide foundation protection method.**

A. No foundation protection required since plot is vacant; however necessary shoring is required.

**Q. Please confirm manufactured rock sand can be used for structural concrete works.**

A. Manufactured rock sand can be used as long it is clean from clay, silt or other impurities that may affect the strength of concrete.

**Q. Can use local sand for block making.**

A. Local washed/dried up sand can be used for block making.

**Q. Kindly provide air condition brand.**

A. Hitachi inverter AC or equivalent

**Q. Kindly provide the distance from the main electrical DB.**

A. The distance from the nearest outdoor DB to the site is approximately 50ft

**Q. Kindly provide AutoCAD drawing.**

A. Auto CAD drawings can be provided after the contractor is awarded the project.

The bid Submission for this package will be held on **Monday, 4<sup>th</sup> July 2016 at 11:00hrs** at **Public procurement Section at Ministry of Finance and treasury.**



Name: Ahmed Mujuthaba



Signature:

