

بِسْمِ اللّٰهِ الرَّحْمٰنِ الرَّحِیْمِ



Ministry of Finance

Ameenee Magu, Male', Republic of Maldives

Telephone: (960) 334 9266, Fax: (960) 332 0706

ދިވެހިސަރުކާރުގެ ގެޒެޓް
މިނިސްޓްރީ އޮފް ފިނޭންސް

CLARIFICATION 1

ކަނޑުވަނަ ސަފުހާ 1

ނަންބަރު No:	TES/2021/W-082	
މަޢުލޫމާތު Project:	Construction of CHSE B- Block Building at Hulhumale', under Contractor Finance	
އުދުހުދު Issued Date	September 21, 2021	
ސަފުހާ ގެ އަދަދު No. of Pages: -02	އެ.އެ.އެ. ގެ އަދަދު BoQ: -0	ވަނަވަނަ Drawings: -00

Please include this clarification when submitting the bid. ފަންޓު ފުރިހަމަކުރުމަށް ބޭނުންކުރާ ބަޔާނުގެ ތެރޭގައި މި ސަފުހާ ގެ މަޢުލޫމާތު ހިމަނާން ޖެހޭނެއެވެ.

➤ Response to the queries raised are attached

ނަންބަރު
Name: Aishath Nadheema

ސަފްޞާ
Signature:



Construction of CHSE B- Block Building at Hulhumale', under Contractor Finance

Project number: TES/2021/W-082

1. What is the condition of existing site? Are there any demolishing works or for cutting trees?
 - a. There won't be any demolition works or cutting down trees to include.
2. Can we get water and electricity for construction work under existing site condition?
 - a. Contractor has to arrange water and electricity for the site.
3. Is there any space for material storage?
 - a. Yes, there will be space for material storage on site.
4. Can we use Manufacture sand for the concrete work?
 - a. Yes, manufactures and can be used for concrete works.
5. Can we use local sand (White sand) made blocks or equivalent for masonry work?
 - a. No, local sand is not acceptable for masonry works.
6. Do we need to include firefighting?
 - a. Yes as per given fire safety layouts in services drawings.
7. Do we need to include Air-conditioning? If yes, please give details, can we use any brand?
 - a. Yes need to include as per BOQ, brand shall be proposed by contractor and approved by MoE.
8. Is this duty-free project?
 - a. No this is not a duty-free project.
9. Can you provide BOQ for this project?
 - a. BoQ has been already provided
10. Do we need to include lift for this project? Can we propose any brand?
 - a. Yes, as per the BoQ need to include lift, brand shall be proposed by contractor and approved by MoE.
11. Can you provide bath ware and fittings details? Like brand name and finishing details PVC finish or chrome finish?
 - a. Contractor has to submit for approval
12. Do we need to include any laboratory equipment? If yes please give details.
 - a. Contractor is not required to provide laboratory equipment.
13. We will not include any furniture for this project.
 - a. Contractor is not required to provide furniture for the project.

