



3 لا تحزن يا موسى

No:	TES/2025/G-002		
Project:	Procurement of materials required for Rooftop Solar Photovoltaic systems of aggregate capacity 1.5MWp for household consumers		
Issued Date	11 th September 2025		
No. of Pages: -02	BoQ: -00	Drawings: -00	

Please include this Clarification when submitting the bid. **بملاحظة** **الرجاء** **إدراج** **هذه** **التوضيحات** **عند** **إرسال** **العرض**

➤ **Please find below the response to the queries raised.**

Queries	Response/Reference Document
1. In the ADDENDUM 3 file, the combiner box has been removed, but the DC Isolator and Surge Protection Device are still on the list. Do we only need to provide these devices?	Yes. Don't need to provide the items removed.
2. Section 6: Schedule of Supply Efficiency >98.2% The bidding document requires that the efficiency of the single-phase inverter be greater than 98.2%. We have communicated with all the manufacturers required in the bidding document and there is no manufacturer that can achieve this efficiency. Generally, manufacturers can meet around 97.5%. Is it acceptable to use inverters with efficiency ranging from 97.5% to 98%?	Maximum efficiency has to be greater than 98.2%.
3. Section 6 - 1.5MW Home Solar REVISED 09.09.2025 PVC Pipe 1" Inch 900 Nos Please confirm the length of the newly added PVC pipe.	Length of each pipe is 5.8 meters
4. Our suppliers already issued the Manufacturer's Authorization with the date of Sep 23th,2025 (according to the day of bid submission in your last email). Can you accept this date of Sep 23th,2025 for the Manufacturer's Authorization?	The previously issued Manufacturer's Authorization is acceptable.
5. We have already asked the manufacturer to open the Manufacturer's Authorization. The date is the previous submission date of September 14th. However, it has been postponed and section 4 of addendum 4 has a new Manufacturer's Authorization format: the date is required to be the new submission date (October 1st). Do we need to	The previously issued Manufacturer's Authorization is acceptable.

change this date?	
-------------------	--

<p>اسم</p> <p>Name: Aminath Naheen Ahmed</p>	<p>امضاء</p> <p>Signature: </p> <p></p>
---	---
