


RO PLANT SCHEDULE FOR HANIMAADHOO ISLAND

NO.	PUMP CAPACITY	MOTOR	POWER SUPPLY	REMARKS
01	10.0M ³ /HRS	25 KW (30.00 HP)	400-110/3PH	TWO NOS OF RO PLANT WORKING ACCORDING TO FLOAT SENSOR



DOOR & LOUVER SCHEDULE

NO.	WIDTH	HEIGHT	DESCRIPTION
D1	2000	2500	STEEL DOOR WITH LOUVERS
D2	800	2000	STEEL DOOR WITH LOUVERS
W1	1000	1000	STEEL FRAME WITH LOUVERS



	CLIENT:	MINISTRY OF ENVIRONMENT AND ENERGY	CONSULTANCY SERVICES FOR DESIGN OF WATER SUPPLY FACILITIES IN Ha.HORAFUSHI, Hdh.HANIMAADHOO, Sh.MILANDHOO, R.UNGOOFAARU, Lh.NAIFARU, Dh,KUDAHUVADHOO, Th.GURAI DHOO AND Ga.VILLINGILI, MALDIVES	DESIGN ENGINEER	DRAWN	CHECKED	APPROVED	SL.NO	DRWING NO	DESCRIPTION
		GREENTECH CONSULTANTS (Pvt.) Ltd IN ASSOCIATION WITH DEVELOPMENT COLLABORATION PARTNERSHIP (Pvt.) Ltd MALDIVES AND OPTIMUM SOLOUTIONS (Pvt) Ltd, MALDIVES	REVERSE OSMOSIS UNIT STRUCTURAL PLANS HANIMAADHOO	DATE	DRG.NO: HANIMAADHOO/RO/05	SCALE: NOT TO SCALE				