

بِسْمِ اللَّهِ الرَّحْمَنِ الرَّحِيمِ

Information Technology Division

Ministry of Health

دائرة تكنولوجيا المعلومات
وزارة الصحة
جسر سقيا

Specification for 3KVA UPS

DETAILS	3000VA(minimum) WITH AUTOMATIC VOLTAGE REGULATOR
OUTPUT VOLTAGE	220V, 230V (nominal), 240V
VOLTAGE DISTORTION FOR OUTPUT	Less than or equal to 5%
OUTPUT CONNECTION QUANTITY	Eight (4) IEC 320 C13 (Minimum) One(1) IEC 320 C19
INPUT VOLTAGE	230V
INPUT CONNECTION TYPE	British BS1363A
BATTERY CONDITION	Leakproof
REPLACEMENT BATTERY COST	Should include current market price for the replacement battery
INTERFACE PORTS	One (1) RJ-45 , One(1) Smart slot or equivalent interface port
AUDIBLE ALARM	Alarm when on battery Alarm when low battery Alarm when overload
REQUIRED FEATURES	Surge protection and Noise filtering Include Emergency Power Off feature LED Display with load and Status
WARRANTY	One-year hardware and TWO years' service warranty One-year Guarantee for Battery (provide replacement if battery life ends earlier than one year)



[Signature]

Aminath Sakha Saleem
Computer Technician
08 November 2020