


BRINE OUTFALL SECTION



BRINE OUTFALL LAYOUT

NOTES:-

1. ALL DIMENSION ARE IN MILLIMETER (MM), UNLESS OTHERWISE NOTED
2. OUTFALL PIPE SHALL BE HDPE PRESSURE PIPE OF GRADE ASTM D 3350, PE 3408, SDR 11
3. THIS DRAWING TO BE READ IN CONJUNCTION WITH ALL OTHER RELEVANT DRAWINGS, GENERAL NOTES AND SPECIFICATIONS.
4. SEA OUTFALL DISPOSAL PIPE SHALL BE FULLY RESISTANT TO WITHSTAND HIGH SALT CONCENTRATION.

REFERENCE DRAWINGS

SL.No	DRAWING No.	DESCRIPTION

REV.	DATE	DESCRIPTION	DRAWN	CHKD	APPRE
0	28.09.'15	DETAILED DESIGN SUBMISSION	JP	SS	MA

REVISION

CLIENT



CONSULTANT:



PROJECT:
 Provision of Water Supply Facilities in 04 islands and Sewerage Facilities in 05 islands - R.Hulhuffaar Island - Republic of Maldives

DRAWING TITLE:
 BRINE OUTFALL LAYOUT & SECTION

DESIGNED	DRAWN	CHECKED	APPROVED	SCALE	DATE
SK	JP	SS	MA	AS SHOWN	28.09.'15
PROJECT No. SHEET No.		DRAWING No.			
K-619 1 OF 1		RH-WS-117			
REV. No.	0				