

Response to Queries for Construction of Hospital at Th.Kinbidhoo

We request you to kindly clarify if it is obligatory to submit the following documents and details listed in the Employer Requirements of the tender at the time of tender submission. We believe that these design and related documents will only be required to be submitted by the successful tenderer after award of contract and during the specific stages of the construction.

1. Clause 1.50.20.1 - Maintenance

a. Totally comprehensive maintenance proposal for all the lifts for a period of three or five years after the first twelve months' defects liability period.

Not required at the bidding stage

2. Clause 8.12-Technical support staff

The tenderer shall provide a list of their technical support staff together with their working experience on PABX system.

Tenderer's technical support staff shall be trained in the principal's regional office on PABX system. Tenderer shall submit a copy of the certificate of training of the staff together with the tender submission.

Tenderer shall indicate the location of their nearest front-line support office, branch office and dealer's office in relation to the proposed site of the PABX. The names and experience of the technical support staff stationed there shall be provided.

Not required at the bidding stage

3. Clause 10.45 - Questionnaire for:-

Pumps

Motor

Starter

4. Clause 11.1 -General requirements for PMGS

A.1 Tenderer shall submit a method statement of pipe fitting & fixing, testing & commissioning with their offer.

Not required at the bidding stage

A.2 Tenderer shall submit certificates from their principal(s) that the principal equipment e.g. plants, manifolds etc. which offered

Not required at the bidding stage

A.3 Tenderer shall submit a list of their qualified personnel who will carry out the installation and commissioning along with their qualification details.

Not required at the bidding stage

A.4 Tenderer should have obtained specialized for Piped Medical Gas Installations in & shall certify that they possess expertise to carry out the installation, testing and commissioning of medical gases supply system at least with 10 years' experience with handling at least 5 major projects where the total project value of each is over US\$ 150,000.00 (Documentary Proof to be submitted)

Not required within project scope



AM

A.5 Supplier will submit a set of testing and commissioning record sheets that they will use during testing & commissioning with their offer as per HTM 02-01 British Standard

Not required at the bidding stage

A.6 The tenderer should have a valid Registration certificate to import the Offered Brand/Model of PMG Equipment to Maldives & a copy of the same to be submitted with the offer.

Not required at the bidding stage

A.7 Missing in the issued tender documents

A.8 The local installation company must have at least 2 Authorized Persons as per HTM 02-01 British standards to handle PMG Projects (These Certificates should be from a recognized & authorized U.K. institute by the U.K. Health Department, which is authorized to train & issue such certificates for PMG Systems as per HTM Standards)

Not required at the bidding stage

A.9 The offered product should have at least over 10 years satisfactory service records in leading Hospitals worldwide where the entire PMG System is with the particular brand (Documentary Evidence to be provided with the tender) Preference will be given to UK products such as "Penlon or Equivalent".

Not required at the bidding stage

A.10 The manufacturer of the offered PMG product should be a company certified as per the latest ISO standards & CE Certificate. Their company should be a company registered to "DESIGN & MANUFACTURE" PMG equipment & not a "DESIGN & ASSEMBLY" Company for entire PMG Range.

Not required at the bidding stage



Handwritten signature